

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS

Brick North (Shell)

Portland, Maine

PANEL	CIRCUIT	WIRE GAUGE	LENGTH	CURRENT DRAW	VOLTAGE DROP	VOLTAGE LOSS	END VOLTAGE	CIRCUIT LOAD
FACP	NAC 4	14	352FT	1.35 A	2.40 VDC	10.00%	21.6 VDC	90%

Calculated @ Maximum Distance/Current