Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/16

4/25/16

Scope of work: Brick North Shell

BH Milliken is adding and relocating devices as needed to extend the fire alarm system into the shell space in the East Wing.

The space will be fully sprinkled. There is an existing addressable fire alarm panel and voice evacuation panel located on the second floor of the West Wing (office space above the circus school).

Norris Inc. will program and test per City of Portland requirements.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/16