NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS							
Brick North (Shell)							
Portland, Maine							
PANEL	**CIRCUIT**	**WIRE GAUGE**	**LENGTH**	**CURRENT DRAW**	**VOLTAGE DROP**	**VOLTAGE LOSS**	**EN VOLT**
FACP	NAC 4	14	352FT	1.35 A	2.40 VDC	10.00%	21.6 V
Calculated @ Maximum Distance/Current							

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/16