



Permitting and Inspections &lt;buildinginspections@portlandmaine.gov&gt;

---

**Fire Suppression System Permit Application 2017-00019 - 1 Thompson's Point**4 messages

---

**Permitting and Inspections** <buildinginspections@portlandmaine.gov>

Wed, Mar 22, 2017 at 8:40 AM

To: Ed Poulin &lt;EPoulin@htfp.me&gt;

Cc: Jonathan Rioux &lt;jrioux@portlandmaine.gov&gt;

RE: Fire Suppression System Permit Application 2017-00019 - CBL: 201 A005001  
1 Thompson's Point

Good morning Ed,

I was able to get in touch with David Petruccelli regarding the additional information he needs to review your fire suppression system application for 1 Thompson's Point.

It turns out that the drawings you submitted were two separate sprinkler plans.

One pair of drawings called for protection of the vertical columns by the sprinkler system, the second pair of drawings did not have that protection.

If there was a change to the drawings the new version should have been submitted with the same name so that the old drawings could be updated.

Also, there was a question as to whether it is necessary to have thermal, and intumescent protection of the steel components.

Please contact Jon Rioux [jrioux@portlandmaine.gov](mailto:jrioux@portlandmaine.gov) T: 756-8187 or 874-8432 to discuss the requirements for this permit application.

All the Best,

Stephanie

Stephanie Hampton

Permit Technician

Permitting and Inspections Department

Room 315, 3<sup>rd</sup> Floor City Hall

389 Congress Street

Portland, ME 04101

Phone: [\(207\) 874-8703](tel:(207)874-8703)Email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

URL: [www.portlandmaine.gov](http://www.portlandmaine.gov)

Office Hours: Monday – Friday 8:00AM - 4:00PM

---

---

**Ed Poulin** <EPoulin@htfp.me>  
To: Jonathan Rioux <jrioux@portlandmaine.gov>  
Cc: Permitting and Inspections <buildinginspections@portlandmaine.gov>

Wed, Mar 22, 2017 at 9:11 AM

Hello Jon,

Attached are the most current sprinkler drawing for the Brick South Building on 1 Thompsons Point.

These drawing show the steel beams in the building being protected via the fire sprinkler system feed.

The state fire marshal's office has these same drawings and has approved this design as adequate.

If you have any questions please feel free to give me a call or I can call your office to discuss.

Thank you.

## Ed Poulin

Design Manager

High Tech Fire Protection

Direct (207) 998-1330

Office (207) 998-2551

Fax (207) 998-4187

[Epoulin@htfp.me](mailto:Epoulin@htfp.me)




**From:** Permitting and Inspections [mailto:[buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)]  
**Sent:** Wednesday, March 22, 2017 8:41 AM  
**To:** Ed Poulin <[EPoulin@htfp.me](mailto:EPoulin@htfp.me)>  
**Cc:** Jonathan Rioux <[jrioux@portlandmaine.gov](mailto:jrioux@portlandmaine.gov)>  
**Subject:** Fire Suppression System Permit Application 2017-00019 - 1 Thompson's Point

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

---

**3 attachments**

-  **Brick South FP-02 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf**  
610K
-  **Brick South FP-01 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf**  
301K
-  **State Permit.pdf**  
235K

---

**Permitting and Inspections** <buildinginspections@portlandmaine.gov>  
To: "Petruccelli, David" <petruccellid@portlandmaine.gov>

Wed, Mar 22, 2017 at 9:28 AM

Hi Dave

I'm forwarding this email from the applicant to you for your information. I will add the revised documents to the G Drive and Eplan.

Steph

Stephanie Hampton

Permit Technician

Permitting and Inspections Department

Room 315, 3<sup>rd</sup> Floor City Hall

389 Congress Street

Portland, ME 04101

Phone: [\(207\) 874-8703](tel:(207)874-8703)

Email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)




URL: [www.portlandmaine.gov](http://www.portlandmaine.gov)

Office Hours: Monday – Friday 8:00AM - 4:00PM

[Quoted text hidden]

---

**3 attachments**

-  **Brick South FP-02 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf**  
610K
-  **Brick South FP-01 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf**  
301K
-  **State Permit.pdf**  
235K

---

**David Petruccelli** <petruccellid@portlandmaine.gov>  
To: Permitting and Inspections <buildinginspections@portlandmaine.gov>

Wed, Mar 22, 2017 at 10:21 AM

Thank you, I will finish the review on Monday.

3/23/2017

City of Portland Mail - Fire Suppression System Permit Application 2017-00019 - 1 Thompson's Point

David

[Quoted text hidden]

--

Capt. David Petruccelli  
**Portland Fire Department**  
**Fire Prevention &**  
**Community Outreach Branch**  
380 Congress St  
Portland, ME 04101

Office: [207-874-8400](tel:207-874-8400)

Mobile: [207-400-7488](tel:207-400-7488)

Fax: [208-874-8410](tel:208-874-8410)