2.1 EAST SECTION 'B'
SCALE 1/8" = 1'-0"

2.3 PLOT PLAN
SCALE: N.T.S.

2 EAST SECTION (WET)
TOTAL PROTECTED AREA 14,500 SQ.FT.
SCALE 1/8" = 1'-0"

2.2 SPRINKLER HEAD DETAIL
SCALE: N.T.S.

DESIGN AREA NUMBER 2

HYDRAULIC DESIGN CRITERIA

LOCATION= CATERING AREA
TYPE OF SYSTEM= NFPA 13 WET
AREA OF OPERATION= 1500-SQ.FT.
NUMBER OF SPRINKLERS= 15
DENSITY= .15 W/ HOSE DEMAND OF 250 GPM
HAZARD CLASS= ORDINARY HAZARD GROUP 1
HEAD SPACING= 120 SQ.FT.

SYSTEM DEMAND INCLUDING HOSE @
BASE OF RISER= 565-GPM 73-PSI
SAFETY MARGIN= 24-PSI

HIGH TECH FIRE PROTECTION
P.O. BOX 156
MINOT, ME. 04258-0258
TEL:(207) 998-2551 FAX:(207) 998-4187
MAINE LICENSE # 102

GENERAL CONTRACTOR ON RECORD:
LANDRY FRENCH CONSTRUCTION
PM: NICK DUNCAN (207) 730-5566
CELL (207) 469-5527

SPECIAL APPLICATIONS:

LEGEND:

- RM/DN PIPE RISER UP OR DOWN
- AUXILIARY DRAIN
- PROPOSED PIPE
- SYSTEM RISER
- PIPE PITCH ¼ MAINS ½ LINES
- SWAY BRACING
- HYDRAULIC CALC. POINT

DESIGN & SYSTEM NOTES:

ALL PIPING 1 1/2" & LARGER TO BE SCHEDULE 10 WITH GROOVED DUCTILE IRON FITTING.

ALL PIPING 1 1/4" & SMALLER TO BE SCHEDULE 40 WITH APPROPRIATE FITTING.

POSITION, LOCATION, SPACING, AND USE OF SPRINKLERS SHALL BE IN ACCORDANCE WITH NFPA 13.

POSITION, LOCATION, SPACING, AND USE OF HANGERS SHALL BE IN ACCORDANCE WITH NFPA 13.

HYDRAULIC CALCULATION PROCEDURES HAVE BEEN DONE IN ACCORDANCE WITH NFPA 13. (SEE PLANS FOR LOCATION OF REMOTE AREAS, HYDRAULIC REFERENCE POINTS, AND SYSTEM DEMANDS.)

HIGH TECH FIRE PROTECTION IS TO BEGIN WORK AT 6" MAIN 1' AFF INSIDE OF BUILDING.

DIMENSIONS AND LOCATIONS GIVEN FOR SPRINKLER HEADS AND PIPE MAY VARY TO ACCOMMODATE ACTUAL FIELD CONDITIONS.

OWNER TO PROVIDE ADEQUATE HEAT THROUGHOUT BUILDING TO PROTECT WATER FILLED PIPING AND EQUIPMENT FROM FREEZING TEMPERATURES.

ONLY TRI-SEAL TYPE COUPLINGS TO BE INSTALLED ON DRY AND OR PRE-ACTION SYSTEMS.

OWNER IS RESPONSIBLE TO MAINTAIN THE SPRINKLER SYSTEM IN ACCORDANCE WITH THE LATEST EDITION OF NFPA 25, "INSPECTION, TESTING, & MAINTENANCE OF WATER-BASED FIRE PROTECTION SYSTEMS" AND/ OR ALL APPLICABLE FEDERAL, STATE, AND/OR LOCAL LAWS, CODES AND ORDINANCES.

ALL MECHANICAL, ELECTRICAL AND PLUMBING TRADES TO COORDINATE THEIR WORK WITH SPRINKLER CONTRACTOR.

ALL ELECTRIC WORK IS TO BE DONE BY OTHERS.

HEAD LEGEND:

GLOBE*
MODEL GL5615
63 /200°
K=5.6
1/2" BRASS UPRIGHT ON THE LINE
DEFLECTORS 1" TO 6" BELOW COMBUSTIBLE CEILINGS

GLOBE*
MODEL GL5626
7 /200°
K=5.6
1/2" BRASS HORIZONTAL SIDEWALL SEMI RECESSED OR EXP.
DELECTOR 4" TO 6" BELOW OVERHEAD DOOR

GLOBE*
MODEL GL5601
70 /155°
K=5.6
1/2" WHITE PENDENT SEMI-RECESSED ESC.

OR APPROVED EQUAL

TOTAL HEADS ON THIS SHEET: 140

SCALE: 1/8"=1'-0"

REVISIONS:

NO.	DATE:	DESCRIPTION:
1	1/16/17	NO STEEL PROTECTION

DATE: DECEMBER 30, 2016
DESIGNER: ED POULIN (RMS# 515)
NICET LEVEL: IV CERT # 108534
CHECKED BY: J. FOSS

LOCATION:
THOMPSONS POINT
PORTLAND, ME

DRAWING TITLE:
BRICK SOUTH
AT THOMPSONS POINT
(MATCHLINE-E)
FIRE PROTECTION PLAN
(NFPA 13 2016ed.)

DRAWING NO.:
FP-02 REVISED