Portland Maine Yes. Google's good here.

Permitting and Inspections <buildinginspections@portlandr

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/02/17

Fire Suppression System Permit Application 2017-00019 - 1 Thompson's Point

4 messages

Permitting and Inspections <buildinginspections@portlandmaine.gov> Wed, Mar 22, 2017 at 8:40 AM
To: Ed Poulin <EPoulin@htfp.me>
Cc: Jonathan Rioux <jrioux@portlandmaine.gov>

RE: Fire Suppression System Permit Application 2017-00019 - CBL: 201 A005001
1 Thompson's Point

Good morning Ed,

I was able to get in touch with David Petruccelli regarding the additional information he needs to review your fire suppression system application for 1 Thompson's Point.

It turns out that the drawings you submitted were two separate sprinkler plans.

One pair of drawings called for protection of the vertical columns by the sprinkler system, the second pair of drawings did not have that protection.

If there was a change to the drawings the new version should have been submitted with the same name so that the old drawings could be updated.

Also, there was a question as to whether it is necessary to have thermal, and intumescent protection of the steel components.

Please contact Jon Rioux **jrioux@portlandmaine.gov T: 756-8187 or 874-8432** to discuss the requirements for this permit application.

All the Best,

Stephanie

Stephanie Hampton

Permit Technician

Permitting and Inspections Department

Room 315, 3rd Floor City Hall

389 Congress Street

Portland, ME 04101

Phone: (207) 874-8703

Email: buildinginspections@portlandmaine.gov

URL: www.portlandmaine.gov

Office Hours: Monday – Friday 8:00AM - 4:00PM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/02/17

Ed Poulin <EPoulin@htfp.me> Wed, Mar 22, 2017 at 9:11 AM
To: Jonathan Rioux <jrioux@portlandmaine.gov>
Cc: Permitting and Inspections <buildinginspections@portlandmaine.gov>

Hello Jon,

Attached are the most current sprinkler drawing for the Brick South Building on 1 Thompsons Point.

These drawing show the steel beams in the building being protected via the fire sprinkler system feed.

The state fire marshal's office has these same drawings and has approved this design as adequate.

If you have any questions please feel free to give me a call or I can call your office to discuss.

Thank you.

Ed Poulin

Design Manager

High Tech Fire Protection

Direct (207) 998-1330

Office (207) 998-2551

Fax (207) 998-4187

Epoulin@htfp.me

From: Permitting and Inspections [mailto:buildinginspections@portlandmaine.gov]
Sent: Wednesday, March 22, 2017 8:41 AM
To: Ed Poulin <EPoulin@htfp.me>
Cc: Jonathan Rioux <jrioux@portlandmaine.gov>
Subject: Fire Suppression System Permit Application 2017-00019 - 1 Thompson's Point

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/02/17

3 attachments

Brick South FP-02 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf
610K

Brick South FP-01 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf
301K

State Permit.pdf
235K

Permitting and Inspections <buildinginspections@portlandmaine.gov> Wed, Mar 22, 2017 at 9:28 AM
To: "Petruccelli, David" <petruccellid@portlandmaine.gov>

Hi Dave

I'm forwarding this email from the applicant to you for your information. I will add the revised documents to the G Drive and Eplan.

Steph

Stephanie Hampton

Permit Technician

Permitting and Inspections Department

Room 315, 3rd Floor City Hall

389 Congress Street

Portland, ME 04101

Phone: (207) 874-8703

Email: buildinginspections@portlandmaine.gov

URL: www.portlandmaine.gov

Office Hours: Monday – Friday 8:00AM - 4:00PM

[Quoted text hidden]

---

3 attachments

Brick South FP-02 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf
610K

Brick South FP-01 REVISED LAYOUT w-STEEL PROTECTION 2-16-17.pdf
301K

State Permit.pdf
235K

David Petruccelli <petruccellid@portlandmaine.gov> Wed, Mar 22, 2017 at 10:21 AM
To: Permitting and Inspections <buildinginspections@portlandmaine.gov>

Thank you, I will finish the review on Monday.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/02/17

David

[Quoted text hidden]

--

Capt. David Petruccelli
Portland Fire Department
Fire Prevention &
Community Outreach Branch
380 Congress St
Portland, ME 04101

Office: 207-874-8400
Mobile: 207-400-7488
Fax: 208-874-8410