

SYSTEM OUTPUTS


CONTROL UNIT ACTIVATION

NOTIFICATION

SYSTEMS CONTROL

SYSTEM INPUTS

		CONTROL UNIT ACTIVATION								NOTIFICATION								SYSTEMS CONTROL	
		A	B	C	D	E	F	G	H	I	J	K	L	M	O	P	Q	R	S
1	MANUAL FIRE ALARM PULL STATION	●	●					●	●	●		●			●			●	●
2	AREA SMOKE DETECTOR	●	●					●	●	●		●			●			●	●
3	AREA HEAT DETECTOR	●	●					●	●	●		●			●			●	●
4	DUCT DETECTOR			●	●			●	●		●						●	●	
5	KITCHEN HOOD SUPPRESSION SYSTEM DISCHARGE	●	●					●	●	●		●			●			●	
6	SPRINKLER WATERFLOW	●	●					●	●	●		●			●				
7	SPRINKLER TAMPER VALVE			●	●			●	●		●						●	●	
8	FIRE ALARM AC POWER FAILURE					●	●	●	●			●			●				
9	FIRE ALARM SYSTEM LOW BATTERY					●	●	●	●			●			●				
10	OPEN CIRCUIT					●	●	●	●			●			●				
11	GROUND FAULT					●	●	●	●			●			●				
12	NOTIFICATION APPLIANCE CIRCUIT SHORT					●	●	●	●			●			●				
		A	B	C	D	E	F	G	H	I	J	K	L	M	O	P	Q	R	S

REVISION 0: SUBMITTAL		01/27/2017
FIRE ALARM MATRIX		
PROJECT NUMBER: 325668SP	SCALE: NONE	
PROJECT:	DRAWN BY: JRS	
BRICK SOUTH THOMPSON'S POINT PORTLAND, MAINE 04102	CHECKED BY: DG	
	SHEET: MX-01	
 <b>Norris Inc.</b> <small>2257 BROADWAY SOUTH PORTLAND, MAINE</small>		