PRODUCT DATA

Series 19HE Pressurized Wet Base Boiler/Burner Unit



Smith Series 19HE cast iron, pressurized, wet base boiler/burner units are ideal for light commercial water or steam heating systems utilizing No. 2 fuel oil, natural gas, or combination gas/oil. Ten different sizes are available, ranging from three-section, 308 MBH I=B=R gross output units to twelve-section, 1750 MBH I=B=R gross output units.

STANDARD FEATURES

- Cast iron wet base sections tested for 80 psi water working pressure,
 15 psi steam working pressure
- · Insulated metal jacket
- Burner mounting plate with insulation blocks
- Front and rear flame observation ports
- · Steel angle floor rails
- Ceramic fiber rope seal between sections
- · Hi-temp hydronic port seals
- Flue brush
- Target walls (3-6 sections)
- · Manual, reset, hi-limit control
- Operating control

ADDITIONAL FEATURES FOR WATER BOILER/BURNER UNITS

- · A.S.M.E. relief valve, 40 psi
- Theraltimeter

ADDITIONAL FEATURES FOR STEAM BOILER/BURNER UNITS

- A.S.M.E. side outlet safety valve,
 15 psi
- Gauge glass with gauge cocks and guards




IBR Ratings, Burner Capacities


Designed and tested to the A.S.M.E. boiler and pressure vessel code, section IV for maximum allowable working pressure, steam 15 PSIG,water 80 PSIG.


									0 1	•		,				
	Boiler	Boiler Horse- power	Heating Surface (Sq. Ft.)	Furnace Volume (Cu. Ft.)	I=B=R Gross Output	Net I=B=R Rating (1) Steam Water			I=B=R Burner Capacity		Draft Loss	Overfire ⁽⁴⁾ Pressure	Water Content (Gals.)		Water Working Weight (Lbs.)	
								Water							, ,	
						(Sq. Ft.)	MBH	MBH	Oil GPH ⁽²⁾	Gas MBH(3)	(in W.C.)	(in W.C.)	Steam	Water	Steam	Water
	†19HE-*-3	9	23.9	2.12	308	963	231	268	2.60	375	0.18	0.28	33.2	38.6	1673.6	1716.8
	†19HE-*-4	12	35.8	3.50	421	1316	316	369	3.60	520	0.18	0.28	41.1	49.2	2057.8	2122.6
	†19HE-*-5	17	47.7	4.88	587	1835	441	510	5.00	725	0.20	0.30	49.0	59.8	2442.0	2528.4
_	†19HE-*-6	22	59.7	6.27	762	2382	572	663	6.50	931	0.23	0.33	56.8	70.3	2825.4	2933.4
	†19HE-*-7	27	71.6	7.65	924	2888	694	803	7.90	1137	0.26	0.36	64.7	80.9	3209.6	3339.2
	†19HE-*-8	32	83.5	9.04	1087	3398	817	945	9.30	1342	0.29	0.39	72.6	91.5	3593.8	3745.0
	†19HE-*-9	37	95.4	10.42	1262	3945	947	1087	10.80	1548	0.32	0.42	80.5	102.0	3978.0	4150.0
	†19HE-*-10	42	107.4	11.81	1424	4504	1081	1238	12.20	1754	0.35	0.45	88.3	112.6	4361.4	4555.8
	†19HE-*-11	46	119.3	13.20	1587	5071	1217	1380	13.60	1989	0.38	0.48	96.2	123.1	4745.6	4960.8
	†19HE-*-12	51	131.2	14.58	1750	5633	1352	1522	15.00	2165	0.41	0.51	104.0	133.7	5129.0	5366.6

- † No insert for oil. Insert prefix "G" for gas or "GO" for combination gas/oil.
- * Insert "S" for steam, "W" for water. Example: GO19HE-S-10 is a 10-section 19HE Series Boiler for steam using combination gas/oil burner.
- (1) The net I=B=R Steam Ratings shown are based on a piping and pickup allowance of 1.333. The I=B=R Water Ratings shown are based on an allowance of 1.15.
- (2) Based on light oil having a heat content of 140,000 BTU per gallon.
- (3) Gas having a heat content of 1,000 BTU/cu. ft. at 0.6 specific gravity.
- (4) Includes 0.10" W.C. pressure on upstream side of exit damper.

Series 19HE







FRONT VIEW

SIDE VIEW

REAR VIEW

Dimensions (inches)												
Boiler		Overall L	ength "A"		- "B"	"C"		Burner Le	"E" Distance Between	"F"		
Number	Carlin	P/FJ	P/FC	Beckett			Carlin	P/FJ	P/FC	Beckett	Supply Tappings	Pipe Diameter
†19HE-*-3	39	44	-	31	9	18	16	21	-	13	12	7
†19HE-*-4	45	50	59	37	15	24	16	21	30	13	18	7
†19HE-*-5	51	56	65	43	21	30	16	21	30	13	24	8
†19HE-*-6	61	62	71	49	27	36	20	21	30	13	30	8
†19HE-*-7	67	68	82	64	33	42	20	21	35	22	36	9
†19HE-*-8	73	74	88	71	39	48	20	21	35	23	42	10
†19HE-*-9	79	80	94	77	45	54	20	21	35	23	48	10
†19HE-*-10	87	86	100	83	51	60	22	21	35	23	54	10
†19HE-*-11	93	-	106	89	57	66	22	-	35	23	60	10+
†19HE-*-12	99	-	112	99	63	72	22	-	35	27	66	10+

The manufacturer should be consulted before selecting a boiler for installations having unusual piping and pickup requirements, such as intermittent system operation, extensive piping, etc.

For forced hot water heating systems where the boiler and all the piping are within the area to be heated, the boiler may be selected on the basis of its Gross Output.

+ 11 and 12 section requires 12" diameter vent pipe. Transition collar provided by Smith.

NOTE: Dimensions are approximate. Should not be used to "rough-in" equipment.

2"

3"

3"

3"

3"

3"

3"

Supply

2"

2"

2-1/2"

3"

3"

3"

3"


3"

4"

4"

Typical Steam Piping Diagram - GATE VALVE 3" STEAM RISER(S SUPPORT DISCHARGE EQUALIZER CONNECTION BOILER WATER LINE ALTERNATE GRAVITY RETURN CONNECTION 2" BELOW MINIMUM BOILER WATER LINE C.W. MAKEUP CONNECTION GATE VALVE PUMPED RETURN CONNECTION BLOWDOWN VALVE __TO DRAIN

No. of									
Boiler Size	3" Risers	Header	Equalizer						
3 thru 5 Section	1	3"	1-1/2"						
6 thru 10 Section	2	4"	2"						
11 thru 12 Section	2	5"	2-1/2"						





WESTCAST, INC. 260 NORTH ELM STREET WESTFIELD, MA 01085 TEL. (413) 562-9613 FAX (413) 562-3799

7555 TRANMERE DRIVE MISSISSAUGA, ONTARIO L5S 1L4 TEL. (905) 672-2991 FAX (905) 672-2883