NOTES:

1. ORIGINAL BUILDING PERMIT DID NOT INCLUDE FRONTAGE REQUIREMENTS

OCCUPANCY:
22 TABLES X 8 SEATS = 176
4,000 S.F. STANDING (7) = 570
176+570 = 746 OCCUPANTS

COMBINED OCCUPANCY OF OUTDOOR ALCOHOL AREA AND BUILDING NEVER TO EXCEED 2500

FOREFRONT BRICK SOUTH, LLC
EXCERPT OF APPROVED BRICK SOUTH LEVEL III SITE PLAN-
OUTDOOR ALCOHOL AREA SITE PLAN
DATE: 2016.12.22 REV. 7 2017.06.07
SCALE: 1" = 40'

CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/12/17