



DUCT SECTIONS

A - (4) 4" CONDUITS	ELECTRICAL SECONDARY
B - (1) 4" CONDUIT	TELEPHONE
C - (3) 5" CONDUITS	ELECTRICAL PRIMARY
D - (1) 4" CONDUIT	TELEPHONE
E - (1) 4" CONDUIT	ELECTRICAL PRIMARY
F - (3) 4" CONDUITS	ELECTRICAL PRIMARY
G - (2) 4" CONDUITS	TELEPHONE
H - (3) 4" CONDUITS	ELECTRICAL PRIMARY
I - (1) 1-1/2" COT	TELEPHONE
J - (2) 5" CONDUITS	ELECTRICAL SECONDARY
K - (1) 2" CONDUIT	ELECTRICAL SECONDARY

- NOTES:**
- WHERE INDICATED, ARRANGE WITH CMP TO PROVIDE A NEW SERVICE RISER POLE.
 - TO THE NEW RISER POLE.
 - SERVICE EQUIPMENT AND SERVICE WIRING SHALL BE AS DESIGNED AND SPECIFIED UNDER THE BRICK NORTH INTERIOR.
 - REMOVAL OF EXISTING SERVICE FROM THE BRICK NORTH INTERIOR SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.
 - WHERE INDICATED, ARRANGE WITH CMP TO PROVIDE A NEW RISE MOUNT SERVICE TRANSFORMER. PUMP STATION FROM POLE #4 TO POLE #5. EXTEND A NEW SECONDARY UNDERGROUND SERVICE FROM THE RECORDED TRANSFORMER TO THE EXISTING MANHOLE. PROVIDE TO THE EXISTING MANHOLE UNDERGROUND SERVICE CONDUCTOR SIZE AND QUANTITY.
 - WHERE INDICATED, PROVIDE TO THE EXISTING MANHOLE UNDERGROUND SERVICE CONDUCTOR SIZE AND QUANTITY.
 - PROVIDE UNDERGROUND CONDUITS FOR TELEPHONE AND CABLE TO CONNECT WITH CONDUITS PROVIDED BY OTHERS.
 - PROVIDE UNDERGROUND CONDUITS FOR SERVICE FROM THE RECORDED TRANSFORMER TO THE EXISTING MANHOLE.
 - PROVIDE UNDERGROUND CONDUITS FOR SERVICE FROM THE RECORDED TRANSFORMER TO THE EXISTING MANHOLE.
 - PROVIDE UNDERGROUND CONDUITS FOR SERVICE FROM THE RECORDED TRANSFORMER TO THE EXISTING MANHOLE.

PRELIMINARY

Bartlett Design
LIGHTING & ELECTRICAL ENGINEERING
742 WASHINGTON STREET, BARTLETT, MD 21015
TEL: (410) 443-3447 FAX: (410) 443-3580

REV	DATE	DESCRIPTION	REVISIONS
2	07/23/14	SUBMITTED FOR UTILITY COMPANY REVIEW	
1	07/01/14	SUBMITTED FOR CLIENT REVIEW	

PROJECT	BRICK NORTH BUILDING AT THE FOREFRONT AT THOMPSON'S POINT
SHEET TITLE	ELECTRICAL SITE PLAN PART 1
CLIENT	FOREFRONT PARTNERS, LP

DRAWN	JLC	DATE	07/01/2014
DESIGNED	LEB	SCALE	1" = 30'-0"
CHKD BY	LEB	JOB NO.	282705