Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/12/15

Exhibit – B3i Warming Hut
The Ice Rink at Thompsons Point

Description:

30’ diameter yurt with engineered snow and wind load upgrades rated at 50 psf, two 36” wide x 6’8” tall ADA compliant egress doors, insulation package, and heat.

Specs:

- 30’ diameter yurt
- Insulated walls
- Two 36” w x 6’8” tall egress doors
- 50 psf snow package: 2”x6” rafters, 2”x4” perimeter studs secured to deck, compression ring-to-rafter bracket.
- Exterior propane heat source.

Image:

Sample image.