DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

THOMPSON'S POINT INC

Located at

1 THOMPSONS POINT

PERMIT ID: 2016-00878

ISSUE DATE: 05/11/2016

CBL: 201 A005001

has permission to

Tent/Staging for "Brandi Carlile" event

5 total items: 4 tents 1 stage, (2 "structures"-pre-fab small buildings-were

approved in another issued permit) Set Up: 05-28-16 Breakdown: 05-30-16 Set Up:

06-03-16 Breakdown: 06-05-16

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White /s/ Tammy Munson

T 11 11 0 001 1 1

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2016-00878 Located at: 1 THOMPSONS POINT CBL: 201 A005001

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 04/13/2016 2016-00878 201 A005001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Pavillion Frame (Depot Building): "Theater & Places of Assembly Tent/Staging for "Brandi Carlile" event & accessory events, 10 Thompson's Pt 5 total items: 4 tents 1 stage, (2 "structures"-pre-fab small buildings were approved in another issued permit) Set Up: 05-28-16 Breakdown: 05-30-16 Set Up: 06-03-16 Breakdown: 06-05-16 **Dept:** Zoning Status: Approved Reviewer: Tammy Munson **Approval Date:** 05/03/2016 Ok to Issue: Note: **Conditions:** 05/03/2016 Building Inspecti Status: Approved **Reviewer:** Tammy Munson **Approval Date:** Dept: Note: Ok to Issue: ✓ **Conditions:** Dept: Fire **Status:** Approved w/Conditions Reviewer: Michael White 05/11/2016 **Approval Date:** Note: Ok to Issue: ✓

Conditions:

- 1) Cooking within the tents has not been reviewed and approved.
- 2) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.
- 3) Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not with 5 feet of the tents or an exit discharge.
- 4) Shall meet the requirements for 2009 NFPA 101, Chapter 11 Special Structures and High Rise Occupancies.
- 5) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 6) All construction shall comply with City Code Chapter 10.

PERMIT ID: 2016-00878 Located at: 1 THOMPSONS POINT CBL: 201 A005001