

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 1001 Westbrook St (Ptid Jetport)		Owner: Delta Airlines		Phone:	
Owner Address:		Leasee/Buyer's Name:		Phone:	
Contractor Name: Northeast Mechanical Corp.		Address: 139 Cash St. So. Portland, ME		Phone: 04106 799-8533	
Past Use: Jetport		Proposed Use: Jetport		COST OF WORK: \$ PERMIT FEE: \$ 40.00 FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied INSPECTION: Use Group: (Type): Signature: [Signature] Date: [Signature]	
Proposed Project Description: Remove Tanks (4)		PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: _____ Date: _____			

Permit No:
940968

Permit Issued:
SEP 13 1994

CITY OF PORTLAND
Zone: CBL: 204-A-001

Zoning Approval:

Special Zone or Reviews:

Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan maj minor mm

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: 9/15/94

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: James Hooper ADDRESS: _____ DATE: 06 Sept 1994 PHONE: 799 8533

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: _____ PHONE: _____

PERMIT ISSUED WITH REQUIREMENTS

CEO DISTRICT 4

M. M. Carroll

COMMENTS

Done

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

BUILDING PERMIT REPORT

Date: 9/12/94
Address: 1001 Westbrook St.
Type of Permit: Remove tanks
Owner: Della Hulin
Contractor: Northwest Mechanical
Applicant: James Harper
Approved: ✓ Denied: _____

Conditions:

1. All underground tank removal(s) and/or ~~installation(s)~~ shall be done in accordance with Department of Environmental Protection Regulations (Chapter 691).
2. No cutting of tanks on site. Cutting of tanks to be done at an approved tank disposal site.
3. Fire Dispatcher must be notified 48 hours in advance of removal and/or transportation of tanks.

**NOTICE OF INTENT
TO ABANDON (REMOVE) AN
UNDERGROUND OIL STORAGE FACILITY**

THIS FORM MUST BE FILED WITH THE D.E.P. AND YOUR LOCAL FIRE DEPARTMENT AT LEAST 30 DAYS PRIOR TO THE SCHEDULED REMOVAL

PLEASE TYPE OR PRINT IN INK:

Name of Facility Owner: Delta Air Lines, Inc. TOC-1, Dept. 594
Mailing Address: Atlanta Int. Airport Telephone #: (404) 714-3999
City: Atlanta State: Georgia Zip Code: 30320
Contact Person (name, address & telephone #): James Greene (404) 714-3237
Mike Messig (207) 879-5121

Name of Facility: Delta Fuel Farm Registration #: 2824
Facility Location (town & street): 1001 Westbrook Street, Portland, Me 04104
Portland International Airport

1. Identify the tanks at this location which are going to be removed:

<u>Tank #</u>	<u>Tank Age</u>	<u>Tank Size (gallons)</u>	<u>Type of Product Stored</u>
1	26 years	10,000	Jet "A"
2	26 years	10,000	Jet "A"
3	18 years	10,000	Jet "A"
4	18 years	550	Sump-Fuel/Water

2. Directions to this facility (be specific): Travel South on Westbrook Street until you reach the stop sign at the end of the road at the Jetport. The "Fuel Farm" will be on your immediate left as you face the main section of the Airport Terminal/Garage. The area is enclosed in a chain link fence and there are some old fuel trucks near

3. Is or was the tank(s) used to store Class I liquids (e.g. gasoline, jet fuel)? Yes No

IF YES, REMOVAL OF THE TANK(S) MUST BE DONE UNDER THE DIRECTION OF A CERTIFIED TANK INSTALLER.

Tank Installer's Name: Leonard Carr Certification Number: #314 Signature: L. Carr
Christopher Littlefield #315 Chris Littlefield

4. Environmental site assessments are required for all tanks except those used for storing heating oil, not for resale, or for farm or residential motor fuel tanks under 1,100 gallons where the product is used on site. **Site Assessor's Name and Address (if applicable):**
NMC Environmental Group, 139 Cash Street, South Portland, ME 04106
207-799-8533 Fax 3853


5. Name and telephone number of contractor who will do the tank removal:
L.C.s Tank Installation & Repair Service Inc., PO Box 168, Athens, Me. 04912
207-654-2935 Fax: 654-3985

6. Expected date of removal (month/day/year): 9/20/94

I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

Date: September 1, 1994 Signature: James W. Hooper
Printed Name and Title: James W. Hooper, Owners Agent
Environmental Site Assessor

**Mail original and yellow copy to DEP; pink copy to fire department; retain gold copy.
RETURN POSTCARD AFTER TANK(S) HAS BEEN REMOVED**



DIVERSIFIED ENVIRONMENTAL SCIENCES, INC.
CONSULTING SCIENTISTS AND ENGINEERS

August 15, 1994

TO: <i>JIM HOOPER</i> <i>LETTER TO STATE</i>	FROM: <i>Ron Lynch - DES</i>	DATE: <i>8/26/94</i>
	FAX #:	FAX # <i>(404) 565-0490</i>

PAGES INCLUDING THIS PAGE: 1

TOPS 14850

State of Maine
UST Program
Bureau of Hazardous Materials and Solid Waste Control
State House, Station 17
Augusta, Maine 04333

RE: FUEL FARM CLOSURE
Delta Air Lines Inc.
Portland International Airport

Dear Sir:

Please allow this letter to serve as the formal thirty (30) day notification that Delta Air Lines, Inc. plans to close the subject fuel farm. The facility consists of three (3) 10,000 gallon Jet A fuel tanks, one (1) 500 gallon gasoline tank, and associated equipment. At this time, we plan to use the services of L.C.'s Tank Installation & Repair Service, Inc. of Athens, Maine for the contractor activities. All work will be performed according to NFPA and API recommended practices. All site assessment work will follow those provided in the State of Maine regulation Chapter 691. Please provide us with any rules, regulations, formats, etc. which might help us perform this project. If you have any questions, please feel free to call.

Sincerely,

Ronald S. Lynch

Ronald S. Lynch, P.G.
Project Manager

- ① Dig Site -
- ② Portland H₂O District
- ③ Port - Sewer District
- ④ Removal form
- ⑤ Permit
- ⑥ Fire Dept.

RSL:c

c: Jim Greene - Delta