

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 1001 Westbrook St		Owner: UNUM		Phone:		Permit No: 341384
Owner Address:		Leasee/Buyer's Name:		Business Name:		
Contractor Name: Murray Construction		Address: P.O. Box 2530 So. Fld, ME 04116-2530		Phone: 799-1136		<div style="border: 2px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED DEC 28 1994 CITY OF PORTLAND Zone: CBL: 204-A-001 </div>
Past Use: Hangar w/office		Proposed Use: Same		COST OF WORK: \$ 45,000. PERMIT FEE: \$ 245.00 FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied INSPECTION: Use Group: U Type: Signature: [Signature]		
Proposed Project Description: Make Interior Renovations as per plans		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: _____ Date: _____		Zoning Approval: _____ Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>		
Permit Taken By: Mary Greak		Date Applied For: 22 Dec 94				Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED
WITH LETTER

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT <i>Ed Morgan</i>	ADDRESS:	DATE: 22 Dec 94	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT 4
M.A. Carroll

COMMENTS

done w/out inspection

Inspection Record

Type

Date

Foundation: _____

Framing: _____

Plumbing: _____

Final: _____

Other: _____

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

December 28, 1994

Murray Construction
P.O. Box 2530
So. Ptld., Me. 04160-2530

RE: 1001 Westbrook St.

Dear Sir,

Your application to make interior renovations as per plans has been reviewed a permit is herewith issued subject to the following requirements: This permit doesn't preclude the applicant from meeting applicable State and Federal laws.

No Certificate of occupancy can be issued until all requirements of this letter are met.

Building Code Requirements

1. Portable fire extinguishers shall be provided in accordance with NFPA #10.
2. The sprinkler system shall be maintained to NFPA #13 standards.
3. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10, section & subsections 1023 & 1024 of the City's building code. (BOCA/1993)
4. The mezzanine shall meet the requirements set forth in Chapter 5 section 505 of the City's building Code. (BOCA/1993).

If you have any questions, please give this office a call.

Sincerely,


P. Samuel Hoffses
Chief of Inspection Services

cc: Lt. Gayland MacDougall - Fire Prevention Bureau