Form # P 01

204-A-001

ELECTRICAL PERMIT
City of Portland, Me.

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 19 August 1996

LOCATION: 987 Westbrook St

Permit # 11182

OWNER Northeast Airmotive **ADDRESS**

								TOTAL	EACH FEE
OUTLETS									
	Receptacles		Switches		Smoke Detector			.20	
FIXTURES	(number of)								
	incandescent		fluorescent					.20	
	fluorescent strip							.20	
SERVICES									
	Overhead				TTL AMPS TO	800		15.00	
	Underground					800		15.00	
TEMPORARY SERV.									
	Overhead				AMPS OVER	800	100	25.00	25.00
	Underground					800		25.00	
METERS	(number of)							1.00	
MOTORS	(number of)							2.00	
RESID/COM	Electric units							1.00	
HEATING	oil/gas units							5.00	
APPLIANCES	Ranges		Cook Tops		Wall Ovens			2.00	
	Water heaters		Fans		Dryers			2.00	
Disposals	Dishwasher		Compactors		Others (denote)			2.00	
MISC. (number of)	Air Cond/win							3.00	
	Air Cond/cent							10.00	
	Signs							5.00	
	Pools							10.00	
	Alarms/res							5.00	
	Alarms/com							15.00	
	Heavy Duty							2.00	
	Outlets								
	Circus/Carnv							25.00	
	Alterations							5.00	
	Fire Repairs							15.00	
	E Lights							1.00	
	E Generators							20.00	
	Panels							4.00	
TRANSFORMER	0-25 Kva							5.00	
	25-200 Kva							8.00	
	Over 200 Kva							10.00	
					TOTAL AMOUNT DUE				
	MINIMUM FEE/COMMERCIAL 35.00				**MINIMUM FEE**		**25.00**		25.00

INSPECTION: Will be ready 8/19 or will call

CONTRACTORS NAME Eastern Electric
ADDRESS 20 Bedford St
TELEPHONE 772-6762
MASTER LICENSE No. 11182
LIMITED LICENSE No.

SIGNATURE OF CONTRACTOR

ELECTRICAL INSTALLATIONS—

Permit Number 11182

Location 987 West Brook Rd

Owner Norwood Bironstone

Date of Permit 8/19/96

Final Inspection 8/19/96

By Inspector [illegible]

INSPECTION: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS: 8/19/96 (Service)

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

DATE:	REMARKS:
8/19/96	grnd rod wire & bonding wire need to go to panel too many under one lug