Form # P 01

ELECTRICAL PERMIT
City of Portland, Me.

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 13 September 1996

LOCATION: 987 Westbrook St

Permit # 11182

OWNER Northeast Automotive **ADDRESS**

								TOTAL	EACH	FEE
OUTLETS										
		Receptacles		Switches		Smoke Detector		78	.20	15.60
FIXTURES		(number of)								
		incandescent		fluorescent				79	.20	15.80
		fluorescent strip							.20	
SERVICES										
		Overhead				TTL AMPS TO	800		15.00	
		Underground					800	800	15.00	15.00
TEMPORARY SERV.										
		Overhead				AMPS OVER	800		25.00	
		Underground					800		25.00	
METERS		(number of)						2	1.00	2.00
MOTORS		(number of)							2.00	
RESID/COM		Electric units							1.00	
HEATING		oil/gas units						2	5.00	10.00
APPLIANCES		Ranges	1	Cook Tops		Wall Ovens			2.00	
		Water heaters	1	Fans	2	Dryers		4	2.00	8.00
Disposals		Dishwasher		Compactors		Others (denote)			2.00	
MISC. (number of)		Air Cond/win						1	3.00	3.00
		Air Cond/cent							10.00	
		Signs							5.00	
		Pools							10.00	
		Alarms/res							5.00	
		Alarms/com							15.00	
		Heavy Duty							2.00	
		Outlets								
		Circus/Carnv							25.00	
		Alterations							5.00	
		Fire Repairs							15.00	
		E Lights							1.00	
		E Generators							20.00	
		Panels						2	4.00	8.00
TRANSFORMER		0-25 Kva							5.00	
		25-200 Kva							8.00	
		Over 200 Kva							10.00	
						TOTAL AMOUNT DUE				
		MINIMUM FEE/COMMERCIAL 35.00				**MINIMUM FEE**		**25.00**		77.40

INSPECTION: Will be ready 9/16 AM or will call

CONTRACTORS NAME Eastern Electric Corp
ADDRESS 20 bedford St Ptld, ME 04101
TELEPHONE 772-6762
MASTER LICENSE No. 11182
LIMITED LICENSE No.

SIGNATURE OF CONTRACTOR

204-A-001

ELECTRICAL INSTALLATIONS—

Permit Number 11182

Location 987 Westbrook St.

Owner Northeast Bromotive

Date of Permit 9/13/96

Final Inspection 3/20/97

By Inspector [illegible]

INSPECTION: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS: 9/16/96 (Conduits)

12/10/96 / _____

3/20/97 Final

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

DATE:	REMARKS:
9/16/96	Slab conduits (OK)
"	VIOLATION OF ART. 5,13 FOUND
12/10/96	must be connected with 1 or 2
"	options
12/10/96	office not ready for final