

State of Maine

No 3167

Department of Public Safety
STATE FIRE MARSHAL'S OFFICE



Augusta, Maine August 19, 1999

In accordance with the provisions of R. S., Title 25, Sec. 2441, as amended, permit is hereby granted for the installation of flammable liquid storage at:

Portland International Jetport
Maintenance Facility, 101 Westbrook St, Portland (1) 10,000 Gal-Split Underground
(location of tank) (capacity) (6,000 Gal-Gasoline,
4,000 Diesel) Aboveground

City of Portland (name of owner)

389 Congress St. (address)

Portland, ME 04101 (address)

One (1) (No. of tanks) L. P. Gas

S.P.C.C. Plan is required.
Below ground piping must meet D.E.P. requirements.
For more information please call 287-2651.

[Signature]
Commissioner

Permit Fee ~~\$5.00~~ 15.00

224-A-001

[Handwritten signature]