

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 01-0971	Issue Date: / /	CBL: 207 B001001
-----------------------	--------------------	---------------------

Location of Construction: 1127 Westbrook St	Owner Name: Northeast Air	Owner Address: 987 Westbrook St	Phone: 207-774-6318
Business Name: n/a	Contractor Name: Barlo Signs	Contractor Address: 155 Maine Mall Road South Portland	Phone: 2078429002
Lessee/Buyer's Name: n/a	Phone: n/a	Permit Type: Signs - Permanent	Zone: AB

Past Use: Commercial / Fuel Center	Proposed Use: Same: Install 156 SqFt Signage.	Permit Fee:	Cost of Work: \$61.20	CEO District: 3
Proposed Project Description: Install 156 SqFt Signage.		FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Signage	
		Signature: <i>[Signature]</i>		
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	Signature: _____ Date: _____	

Permit Taken By: cjh	Date Applied For: 08/08/2001	Zoning Approval		
-------------------------	---------------------------------	------------------------	--	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: 9/10/01 OGA	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: _____
---	--	---	---

APPROVED PER REVISION UNDER SECS. 14-368.5g + 14-526 OF SITE PLAN ORDINANCE, w/ CONDITION THAT THE SIGN EXTERIOR FACE EAST/WEST, OR THAT THE NORTH-FACING SIDE NOT BE ILLUMINATED.

PERMIT ISSUED WITH REQUIREMENTS

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

THIS IS NOT A PERMIT/CONSTRUCTION MAY NOT COMMENCE UNTIL THE PERMIT IS ISSUED

SIGNAGE APPLICATION

THIS IS NOT A PERMIT
CONSTRUCTION CANNOT NOT COMMENCE UNTIL THE PERMIT IS ISSUED

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

1127 Westbrook St

Location/Address of Construction: NORTH RAMP PORTLAND INTERNATIONAL AIRPORT

Total Square Footage of Proposed Structure 156 sq. ft. Square Footage of Lot 48,510 ±

Tax Assessor's Chart, Block & Lot Number 207-B-001-005 ~~207~~
210-C-1,3
Chart# 207 Block# B Lot# 001
Owner: NORTHEAST AIRMOTIVE Telephone #: 774-6318

Lessee/Buyer's Name (If Applicable) Owner's/Purchaser/Lessee Address: 987 WESTBROOK ST.
PORTLAND, MAINE
Total s.f. of signs 156 x .20 \$ 31.20, plus \$30.00
TOTALS 61.20

Current use: AVIATION Proposed use: SAME

Project description: REPLACE REMOVED IRVING AVIATION SIGN WITH NEW EXXON SELF SERVE SIGN AS ATTACHED

Applicants Name, Address & Telephone: NORTHEAST AIRMOTIVE 774-6318
987 WESTBROOK ST.
PORTLAND, ME 04102
Contractor's Name, Address & Telephone: EXXON - BARLO SIGN
Who shall we contact when the permit is ready: STEPHEN WALKER
Telephone: 774-6318
If you would like it mailed, what mailing address should we use: 987 WESTBROOK ST.
PORTLAND, ME.
Rec'd By: 8/8
ctt

**THIS IS NOT A PERMIT/CONSTRUCTION MAY NOT COMMENCE UNTIL THE
PERMIT IS ISSUED**

If the property is located in a HISTORIC DISTRICT, a separate sketch is required indicating the design, dimensions, construction materials and source of illumination if any. A photograph of the building façade should be submitted, showing where each sign is to be installed.

Certification

I hereby certify that I am the Owner of record of the named property, or that the owner of record authorizes the proposed work and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>Stephen M. Walker</i>	Date: <i>August 7, 2007</i>
--	-----------------------------

Sign Permit Fee: \$30.00 plus \$0.20 per square foot.

A building permit is also required for any awning based on cost of work-\$30.00 for the first \$1,000.00 and \$6.00 for each additional \$1,000.00

**BY FILLING OUT THIS APPLICATION IS DOES NOT MEET THAT
YOU WILL BE APPROVED FOR THE AMOUNT OF SIGNAGE YOU
ARE APPLYING FOR**

**IT IS SUGGESTED THAT YOU DO NOT ORDER ANY SIGNAGE UNTIL
YOU HAVE RECEIVED YOUR SIGN PERMIT THAT HAS BEEN
SIGNED BY THE BUILDING, ZONING AND POSSIBLE HISTORICAL
OFFICIALS OF THIS OFFICE**

BUILDING PERMIT REPORT

DATE: 13 August 2001 ADDRESS: 1127 Westbrook St. CBL: 207-B-001
 REASON FOR PERMIT: Signage
 BUILDING OWNER: Northeast Air
 PERMIT APPLICANT: _____ CONTRACTOR: Barlo Sign
 USE GROUP: _____ CONSTRUCTION TYPE: _____ CONSTRUCTION COST: _____ PERMIT FEES: \$61.20


The City's Adopted Building Code (The BOCA National Building Code/1999 with City Amendments)
 The City's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions shall be met: *1, *37

1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection) **"ALL LOT LINES SHALL BE CLEARLY MARKED BEFORE CALLING."**
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' O.C. between bolts. Section 2305.17
5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete and masonry. Concrete Sections 1908.9-19.8.10/ Masonry Sections 2111.3-2111.4.
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1999)
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42". In occupancies in Use Group A, B.H-4, I-1, I-2, M, R, public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. Handrails shall be a minimum of 34" but not more than 38". Exception: Handrails that form part of a guard shall have a height not less than 36 inches (914 mm) and not more than 42 inches (1067 mm). Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0). Handrails shall be on both sides of stairway. (Section 1014.7) R-3 (ONE & TWO FAMILY DWELLINGS) GUARD HEIGHT IS 36" MINIMUM.
12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 1/4" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
15. The Minimum required width of a corridor shall be determined by the most restrictive of the criteria ~~with~~ section 1011.3 but not less than 36".
16. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508)mm, and a minimum net clear opening of 5.7 sq. ft. (Section 1010.4)
17. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
18. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closure's. (Over 3 stories in height requirements for fire rating is two (2) hours. (Section 710.0)
19. The boiler shall be protected by enclosing with (1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)

20. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1999), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements
21. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
22. The Fire Alarm System shall be installed and maintained to NFPA #72 Standard.
23. The Sprinkler System shall be installed and maintained to NFPA #13 Standard.
24. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1999)
25. Section 25 - 135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
26. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
27. Ventilation and access shall meet the requirements of Chapter 12 Sections 1210.0 and 1211.0 of the City's Building Code. (Crawl spaces & attics).
28. All electrical, plumbing and HVAC permits must be obtained by Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
29. All requirements must be met before a final Certificate of Occupancy is issued.
30. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (The BOCA National Building Code/1996).
31. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical code (The BOCA National Mechanical Code/1993). (Chapter M-16)
32. Please read and implement the attached Land Use Zoning report requirements.
33. Boring, cutting and notching shall be done in accordance with Sections 2305.3, 2305.3.1, 2305.4.4 and 2305.5.1 of the City's Building Code.
34. Bridging shall comply with Section 2305.16.
35. Glass and glazing shall meet the requirements of Chapter 24 of the building code. (Safety Glazing Section 2406.0)
36. All flashing shall comply with Section 1406.3.10.
- * 37. All signage shall be done in accordance with Section 3102.0 signs of the City's Building Code, (The BOCA National Building Code/1999).


 P. Samuel Hoffes, Building Inspector
 Cc: Lt. McDougall, PFD
 Marge Schmuckal, Zoning Administrator
 Michael Nugent, Inspection Service Manager

PSH 10/00

****This permit is herewith issued, on the basis of plans submitted and conditions placed on these plans, any deviations shall require a separate approval.**


...THIS PERMIT HAS BEEN ISSUED WITH THE UNDERSTANDING THAT ALL THE CONDITIONS OF THE APPROVAL SHALL BE COMPLETED. THEREFORE, BEFORE THE WORK IS COMPLETED A REVISED PLAN OR STATEMENT FROM THE PERMIT HOLDER SHALL BE SUBMITTED TO THIS OFFICE SHOWING OR EXPLAINING THAT THE CONDITIONS HAVE BEEN MET. IF THIS REQUIREMENT IS NOT RECEIVED YOUR CERTIFICATE OF OCCUPANCY SHALL BE WITHHELD. (You Shall Call for Inspections)

******ALL PLANS THAT REQUIRE A PROFESSIONAL DESIGNER'S SEAL, (AS PER SECTION 114.0 OF THE BUILDING CODE) SHALL ALSO BE PRESENTED TO THIS DIVISION ON AUTO CAD LT. 2000, DXF FORMAT OR EQUIVALENT.**


*******CERTIFICATE OF OCCUPANCY FEE \$50.00**

PROPERTY PLAN

1067-1095 Westbrook Street
Portland, Maine



*PORTLAND JETPORT
NORTH RAMP*



Zoning: AB - Airport Business


Scale: 1" = 500 Ft.

MAP REF: 207-B-1-5
210-C-1, 3


BUILDING PLANS

1067-1095 Westbrook Street
Portland, Maine

Scale: 1" = 60 Feet



FLOOD MAP



NATIONAL FLOOD INSURANCE PROGRAM


FIRM
FLOOD INSURANCE RATE MAP

CITY OF
PORTLAND,
MAINE
CUMBERLAND COUNTY

PANEL 12 OF 17
(SEE MAP INDEX FOR PANELS NOT PRINTED)

COMMUNITY-PANEL NUMBER
230051 0012 C

MAP REVISED:
DECEMBER 8, 1998



Federal Emergency Management Agency

7

→
REINSTALL
SIGN
WHERE
IRVING'S
WAS







W.O.#:

SCOPE OF WORK BARLO

> MANUFACTURE & INSTALL (1) D/F ILLUMINATED PYLON SIGN ON EXISTING CONCRETE PAD

SCOPE OF WORK BARLO/EX

SCOPE OF WORK SIGN SUB

GENERAL NOTES

COLORS

SIGN
 Cabinet: PTM S/G BLACK
 Backliner: PTM S/G BLACK
 Face B/G: FORMED WHITE LEXAN FACES
 Copy: ALL COLORS PER CORPORATE STANDARDS REQUIRED PRIOR TO PRODUCTION

POLES

Pole: BLACK
 Pole Cover:

SIGN DISPOSITION


- Site re for Barbs
- Leave @ Site
- Disposal
- Store for Customer
- On in garage
- N/A

ALL COLORS ARE FOR REPRESENTATION ONLY. SEE ACTUAL SAMPLES FOR COLOR MATCH. ALL FINISHES TO BE SEW-GLASS UNLESS OTHERWISE NOTED.



GENERAL INFO

Qty: ONE Sq. Ft.: 1573
 S.F. (DP) (ILL) Non-ILL



Type:	Ma.:	Re. Size:	Box Depth:	Draw Released for production:	By:
Face Ma.:	Thickness:	Copy:		Rev. #	Date
Pole Cover Ma.:	Hg.:	Depth:		Description	To Shop / By
Interior	Exterior	Face-Lit	Back-Lit	Drain Holes: Y N	
Face Ma.:	Th:	Return Ma.:	Depth:		
Mylar Size:	Back Ma.:	Neon Rows:	MM:		
Trans. Location:	30 MA 40 MA	Wiring: % BK % Lights	Wiewey N/A		
Housings: Glass PK's	DbL Backs N/A	M.g. Nu. Ser.	Thru Back < Clip	Engineering:	Production:
				Check By:	Survey:
					Estimating:
					Sales:


Aug 24 01 12:23p

Howie Strachan

781-273-5037

p.2

Post-it® Fax Note	7671	Date	8/29	# of pages	2
To	JEFFREY HAROLD	From	STEVE WALKER		
Co./Dept.		Co.	NEA		
Phone #	800-825-8258	Phone #	774-6318		
Fax #	256-8258	Fax #	874 4714		




Component Dimensions in Feet and Inches

System	A	B	W	H1	H2	C	D
70	11'-11"	24' or 30'	11'-3"	8'-1.75"	3'-8.25"	28.25"	18.85"
40	8'-8.5"	20' or 24'	8'-1.5"	4'-5.5"	2'-8.25"	18.5"	13.50"
30	8'-8"	18', 20' or 24'	7'-4"	4'-0.44"	2'-5.31"	17.8"	12.28"
20	8'-8.5"	18' or 20'	8'-0.5"	3'-3.7"	2'-0.5"	13.7"	9.75"

Actual Sign Area in Square Feet (Nominal Area Shown in Parenthesis)

System	I.D.	Ancillary	I.D. & Ancillary
70	69.14 (70)	41.42 (42)	110.56
40	36.22 (40)	21.84 (22)	58.06
30	29.60 (30)	17.91 (18)	47.51
20	19.99 (20)	12.34 (12)	32.33



Component Dimensions in Feet and Inches

System	A	B	W	H1	H2	C	D
40	8'-1.5"	20' or 24'	8'-1.5"	4'-8.5"	2'-8.25"	18.90"	13.50"
30	8'-6"	18' or 20'	7'-6"	4'-0.44"	2'-5.31"	17.00"	12.20"
20	7'-0.5"	16', 18' or 20'	6'-0.5"	3'-3.7"	2'-0.5"	13.70"	9.75"

Actual Sign Area in Square Feet (Nominal Area Shown in Parenthesis)

System	I.D.	Ancillary	I.D. + Ancillary
40	38.22 (40)	21.84 (22)	58.06
30	28.80 (30)	17.91 (18)	47.51
20	19.98 (20)	12.34 (12)	32.33

70 System Not Available in Single Pole System

EXXON Company, U.S.A.
Houston, Texas

Standard Single Pole
Sign System

Date : 11/23/93
Rev. :

Drawing No.
Avi-3A



CITY OF PORTLAND
Planning and Urban Development Department

MEMORANDUM

TO: Marge Schmuckal, Zoning Administrator
✓ FROM: Deborah Andrews, Senior Planner *D. Andrews*
DATE: May 7, 1996
SUBJECT: Irving Aviation Sign at Portland Jetport

The existing Irving Aviation sign at the Portland Jetport has been reviewed under Sec. 14-526 of the Site Plan Ordinance and has been found to meet the standards of this section. Therefore I recommend approval, with the condition that the north facing side of the sign be altered to eliminate commercial messages of any kind and that all illumination of this face be eliminated.

O:\PLAN\HPCORRESP\IRVAVIA.WPD

RE: Free Standing Sign

03/26/1996 12:59 2077747740

PWM JETPORT

PAGE 02

Portland International Jetport
Jeffrey Schultes, A.A.E.
Manager



Transportation and Waterfront Dept.
Thomas F. Valleau
Director

CITY OF PORTLAND

27 October 1995

Irving Aviation Services
Portland International Jetport
Portland, ME 04102

Dear Al,

The Portland International Jetport has reviewed your sign proposal and does approve the installation with the following comments and conditions:

1. A suggestion is made that the Unicom frequency be larger so as to be seen by pilots.
2. We need to see detailed sketches of footing details and location of sign to assure that it will not conflict with existing underground utilities/sewers.
3. If existing payment is removed it must be replaced and sealed.
4. Contractor must meet security requirements.
5. Size of crane (height) must be known and scheduled with the airport prior to construction.
6. Confirmation that sign height will not exceed 115 MSL elevation.

Sincerely,

Jeff Schultes, A.A.E.
Airport Manager

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Permit No: **960333**

Location of Construction: 1127 Westbrook St		Owner: Irving Oil Corp		Phone:	
Owner Address:		Leasee/Buyer's Name:		Business Name:	
Contractor Name: Irving Oil Co. - Christopher D. Watson		Address: 1127 Westbrook St Portland, ME 04102		Phone: 775-5635	
Past Use: Jetport		Proposed Use: Same w/signage		COST OF WORK: \$	
				PERMIT FEE: \$	
				INSPECTION: Use Group: Type: <i>BOCA</i>	
Proposed Project Description: Erect signage totalling 342 sq ft		Signature:		Signature: <i>[Signature]</i>	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
		Action:		Date:	
Permit Taken By: Mary Gresik		Date Applied For: 25 April 1996			

PERMIT ISSUED
Permit Issued:
MAY - 2 1996
CITY OF PORTLAND

Zone: *AB* CBL:

Zoning Approval: *[Signature]*

Special Zone or Reviews:

Shoreland *denied*

Wetland *5/1/96*

Flood Zone

Subdivision

Site Plan major minor mm

Zoning Appeal

Variance

Miscellaneous *However*

Conditional Use *Free STAN*

Interpretation

Approved *Sign APPROVED*

Denied *by Deb Andrews see memo*

Historic Preservation

Not in District or Landmark

Does Not Require Review

Requires Review

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT *[Signature]* Christopher Watson ADDRESS: DATE: 25 April 1996 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

CEO DISTRICT **4**
[Signature]

2E PA11
30" x 9

7c



Aviation Services

UNICOM 123.50

FBO

Character and graphic sizes:
 Aviation Services logo-
 Height- 45.75"
 Width- 190"
 Aviation Services-
 Height- 16.5"
 Width- 188"
 UNICOM 123.50-
 Height- 10"
 Maximum readable distance- 450'
 Width- 105"

FBO-
 Height- 35"
 Width- 122"

60"

Seam

31"

2-1/4" H-BAR-
 Dark Blue vinyl
 applied to face of
 H-Bar.

29"

648" = 54' tall