To: Chris Allain

Great Falls Construction

From: Charlie Wilson

Date: May 23, 2012

Subject: Enterprise Rent-a-Car, Portland Jetport

Portland Pump has installed the aboveground tank system, underground piping and pump in accordance with the requirements of the State Fire Marshall's Aboveground Motor Fuel Regulations, Maine DEP Chapter 691 Rules and NFPA Chapters 30 and 30A.

Attached is the State Fire Marshall Aboveground Storage Tank site permit.