389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Phil Doughty **From:** Mike Nugent

Fax: 781-2908 **Date:** May 12, 2004

Phone **Pages:** 1

Re: Jetport Baggage expansion (208_A001)

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

I have commenced a partial review the submissions for the above permit and have the following questions:

1) There is no Statement of Special Inspections pursuant to Section 1705 of the Code.
2) Need a statement from the Structural Engineer certifying the ability of the existing structure to perform satisfactorily with the new Loads.
3) I didn't find the Geotechnical report, was a copy sent?
4) Planning has not signed off on the project as of this date and time.