



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION 1001 Westbrook St

CBL 208 A001002

Issued to Delta Air Lines Inc/City of Portland

Date of Issue 12/11/2003

**This is to certify** that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 03-1236, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire elevated walkway from Southeast corner or terminal to apron grade

APPROVED OCCUPANCY

Elevated walkway from main terminal to aircraft boarding apron

**Limiting Conditions:**

Use is limited to actual capability of structure to perform. Structure does not meet BOCA 99 wind and snow requirements. Human occupancy is limited in numbers as not to exceed the 40 lbs./s.f. Design (see conditions of permit)

**This certificate supersedes certificate issued**

Approved:

12/11/03  
12/11/03  
JKK. P.F.D.  
12/12/03  
12/11/03  
Inspector

Inspector of Buildings 12/15/03

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.