



22

26

FIELD VERIFY SIZE OF SPRINKLER MAIN.  
PROVIDE 2 1/2" MONITORED ISOLATION VALVE.  
VALVE SHALL BE LOCKED OPEN.

2 1/2"

2 1/2" SPR DROP

2 1/2" WS UP

Item	Date

THE SHIPYARD  
BREWING COMPANY  
68 Main Street  
Portland, ME 04101  
(603) 785-0844

**The Shipyard**  
Main Terminal - Lower Level  
Portland International Jetport  
1001 Westbrook Street  
Portland, ME 04102

**IMS Host**  
6600 Rockledge Drive  
Bethesda, MD 20817  
Ph: (301) 656-4025  
Fax: (301) 594-1175

**LAM Foodservice  
DESIGN GROUP**  
811 Cornwell Park Drive  
Glen Burnie, MD 21061  
Ph: (410) 863-1302  
Fx: (410) 863-1308

**Building Engineering  
Resources, Inc.**  
28 Main Street, Bldg. 43A  
North Farnam, MA 02156  
Tel: (508) 234-0200  
Fax: (508) 234-0200  
E: kevin@buildingresources.com

**LLOYD ARCHITECTS**  
Two High Cliff, Plymouth MA 02360  
TEL: (508) 746-4646  
FAX: (508) 746-1226  
E-MAIL: info@lloydarch.com

Job No.: 072117  
Scale: 1/4"=1'-0"  
Issued: 12/11/07

Fire Protection  
Basement Plan

**FP2**