



ELECTRICAL DEMOLITION PLAN
SCALE: 1" = 40'-0"

GENERAL DEMO NOTES:

- D1 - REMOVE AND DISCONNECT ALL EXISTING ELECTRICAL EQUIPMENT WITHIN AREAS INDICATED, UNLESS OTHERWISE NOTED TO REMAIN, INCLUDING LIGHTING FIXTURES, SWITCHES, RECEPTACLES, EXPOSED CONDUITS, TRAYS, ETC. ALL EXPOSED ABANDONED CONDUCTORS AND CONDUITS SHALL BE REMOVED WHERE COMPLETE REMOVAL IS NOT ABANDON ALL CONDUITS AS REQUIRED. COORDINATE REMOVAL WITH ENGINEER.
- D2 - EXISTING ELECTRICAL EQUIPMENT NECESSARY FOR EXISTING INSTALLATION, BUT PASSING THROUGH THE RENOVATED AREA, SHALL BE IDENTIFIED, AND ALL CONDUITS, BRANCH CIRCUITS AND FEEDERS PASSING THROUGH RENOVATED AREAS AND SERVICING UNDISTURBED AREAS.
- D3 - EXISTING CONDUIT FOUND TO BE REUSABLE MAY BE USED. ALL OTHERS SHALL BE REMOVED FROM THE JOB SITE UNLESS OTHERWISE SPECIFIED BY THE ENGINEER.
- D4 - REMOVE EXISTING COMMUNICATIONS WIRING AND BRANCH CIRCUITS CONSISTENT WITH GENERAL CONTRACTOR FROM TO REMOVAL.
- D5 - CONTRACTOR SHALL CARRY ALL COSTS RELATING TO REMOVAL AND REPAIR OF ELECTRICAL EQUIPMENT/WORKMANSHIP PRIOR TO ACTUAL REMOVAL OF ELECTRICAL EQUIPMENT. CONTRACTOR SHALL COORDINATE WITH OWNER FOR POSSIBLE SALVAGE OF ANY OF THE EQUIPMENT.
- D6 - THE ELECTRICAL DEVICES AND LIGHTING FIXTURES INDICATED ON THIS DRAWING REPRESENT EQUIPMENT TAKEN FROM EXISTING PLANS AND SHALL BE REMOVED FROM THE PROJECT. CONTRACTOR SHALL NOT REPRESENT ALL EQUIPMENT AND WIRING WITHIN THE DEMOLITION AREA. THIS DRAWING HAS BEEN PREPARED TO ASSIST THE CONTRACTOR IN THE IDENTIFICATION OF ALL EXISTING ELECTRICAL EQUIPMENT AND WIRING. ALL EXISTING CONDITIONS, NO EXTRA COMPENSATION OR TIME EXTENSION WILL BE PERMITTED BECAUSE OF LACK OF COMPLIANCE WITH THIS REQUIREMENT.
- D7 - THE ELECTRICAL CONTRACTOR SHALL TAKE INTO ACCOUNT IN PLING THE REMOVAL OF EXISTING ELECTRICAL EQUIPMENT AND WIRING AND MODIFICATION OF EXISTING ELECTRICAL EQUIPMENT OR LIGHTING CONDUIT AND RELATED ITEMS FOR THEIR REPLACEMENT OR REPAIR AS SPECIFIED OR AS MAY BE NECESSARY.
- D8 - THE E.C. SHALL COORDINATE CLOSELY WITH THE OWNER AND FIELD SUPERVISOR TO DETERMINE THE SCOPE OF THE WORK. ALL ITEMS OF WORK TO BE REMOVED OR PROTECTED

ADDITIONAL SCOPE OF WORK

- 1. THE ELECTRICAL CONTRACTOR SHALL PROVIDE TEMPORARY ELECTRICAL SERVICE TO FIELD TRAILERS USED BY ALL TRADES.
- 2. THE ELECTRICAL CONTRACTOR SHALL PROVIDE TEMPORARY RAINWATER AND PARKING AREA LIGHTING AS NECESSARY DURING CONSTRUCTION OF THIS PROJECT.

ELECTRICAL DEMOLITION LEGEND:

////// DENOTES EQUIPMENT TO BE REMOVED

If this sheet is less than 30" x 42" in size, it has been reduced. Graphic scales must be adjusted accordingly.

DOMENECH HICKS & KROCKWALING ARCHITECTS
155 Massachusetts Ave.
Boston, MA 02115
617-267-6408
Fax 617-267-1990

Static
Static Consulting Services Inc.
22 Free Street, 2nd Fl.
Boston, MA 02114
Tel. 207-775-3211
Fax 207-775-6434
www.static.com

CONFORMED SET FOR FIELD USE

CITY OF PORTLAND
PORTLAND, MAINE
DEPARTMENT OF WATERFRONT AND TRANSPORTATION

PMI
PORTLAND INTERNATIONAL JETPORT
PHASE II
PARKING GARAGE
1001 WESTBROOK ST.,
PORTLAND, MAINE

ELECTRICAL SITE DEMO PLAN
ED-1
Job No. 18510128
Date 02/28/08