

R. W. Gillespie & Associates, Inc.

86 Industrial Park Road, Suite 4, Saco, ME 04072
200 International Drive, Suite 170, Portsmouth, NH 03801
ME 207-286-8008; Fax: 207-286-2882
NH 603-427-0244; Fax: 603-430-2041

LETTER OF TRANSMITTAL

Doughty & Associates, Inc.

362 U.S. Route One

Falmouth, Maine 04105

Date:	January 25, 2005	Project No.:	438-05
Attention:	Mr. Phillip Doughty (pdarch@maine.rr.com)		
Re:	New Jetways & Addition to Baggage Claim Laboratory Testing Portland, Maine		

We are sending you attached laboratory test results.

Laboratory No. (s)	Test (s) Performed
01/05/05	Visual Inspection Report

Remarks:

Copy To: Roy Williams (rsw@portlandmaine.gov)
Cuyler Feagles, Clerk of the works (pda1001@aol.com)

Signed: Suzan A. Bullock

If enclosures are not as noted, kindly notify us at once.

Quality Assurance Labs Inc.

NON-DESTRUCTIVE TESTING AND INSPECTION SERVICES
80 PLEASANT AVENUE • SOUTH PORTLAND, MAINE 04106 • TEL: (207) 799-8911 • FAX: (207) 799-7251

FILE RECALL; C:\QAL05009.DOC

05 JANUARY 2005

R.W. GILLESPIE & ASSOCIATES, INC.
86 INDUSTRIAL PARK ROAD, SUITE 4
SACO, MAINE 04072

RE: PORTLAND AIRPORT TERMINAL EXPANSION
PORTLAND, MAINE
QAL-05-009
PROJECT# 438-05

ATTN: ROBERT GILLESPIE

THIS LETTER WILL SERVE AS MY REPORT FOR THE VISUAL INSPECTION ON 05 JAN05.
INSPECTION WAS PERFORMED ON:

2 (TWO) MOMENT CONNECTIONS Z.1.47 AND Z.1.48.5. THIS IS GROUND LEVEL
NORTHEAST CORNER OF BUILDING. VISUAL IN LIEU OF UT PER TELCON WITH TODD.

BOTH MOMENT CONNECTIONS WERE FOUND ACCEPTABLE.

IF YOU HAVE ANY QUESTIONS, PLEASE CALL ME AT 207-799-8911.

SINCERELY,

RYAN RUSSELL
LEVEL II CWI#04050331

MTG