R. W. Gillespie & Associates, Inc.

86 Industrial Park Road, Suite 4, Saco, ME 04072 207-286-8008 200 International Drive, Suite 170, Portsmouth, NH 03801 603-427-0244

LETTER OF TRANSMITTAL

| | Date: | Project N | o.: |
|----------------------------|------------|--------------------------|------------------|
| | Aug | gust 17, 2004 | 438-05 |
| | Attention: | | |
| | M | r. Phillip Doughty (pdar | ch@maine.rr.com) |
| | Re: | | |
| Doughty & Associates, Inc. | Co | oncrete Testing | |
| | Ne | ew Jetways & Addition | to Baggage Claim |
| 362 U.S. Route One | Po | rtland Jetport | |
| | Po | rtland, Maine | |
| Falmouth, ME 04105 | | | |
| | | | |

| | We are sending t | ou attached concrete cylinder test results. | |
|------------------|------------------|---|--|
| Cylinder No. (s) | | Age (Days) | |
| | 47111 47112 | 28 28 | |
| | | | |

Remarks:

Copy To: Roy Williams (rsw@ci.portland.me.us)

Signed:

Bertha Dawn

R. W. GILLESPIE & ASSOCIATES, INC.

Page 1 of 1

86 Industrial Park Road, Suite 4, Saco, ME 04072 207-286-8008 200 International Drive, Suite 170, Portsmouth, NH 03801 603-427-0244 CONCRETE TEST/PLACEMENT REPORT

Project Name:

New Jetways & Addition to Baggage Claim

Date Cylinders Cast:

20-Jul-04

Project No:

438-05

Concrete Supplier:

Auburn

Weather Conditions:
Method of Placement:

Mostly Cloudy

General Contractor: Design Strength:

Ledgewood

Admixtures:

Truck Discharge

Max Agg. Size:

3,000 3/4"

Placement Location:

Footing from W - 48.5 to W.5 - 48.5 to W.5 - 49.8 to W - 49.8

Test Cylinder Location: W.5 - 48.5

Date Report Issued: AUG 18 2004

| 6x12 Cylinders | 4 | Cast by | Ryan MacEachern | Time | | |
|----------------|--------|--------------------------|-----------------|------|------------|------|
| Load No. | 1 | Slump (in) ASTM C 143 | 2.75 | | Batched @ | 1:50 |
| Ticket No. | 065932 | Air (°F) | 85 | | Arrived @ | 2:05 |
| Truck No. | 81 | Concrete (°F) ASTM C 10 | 64 79 | | Total Time | 60 |
| Cubic Yds. | 4 | Air Content (%) ASTM C 2 | 31 4.6 | | | |

^{*}Concrete sampled by ASTM C 172

Specimen Storage ASTM C 31: Field cure days: 1

Date received: 21-Jul-04 Condition of Cylinders: Good

| Lab No. | Test Date | Avg Dia (in) | Area (in²) | Age (Days) | Load (lbs) | Compressive Strength (psi) | Break type |
|---------|-----------|--------------|------------|------------|------------|----------------------------|------------|
| 47110 | 27-Jul-04 | 6.007 | 28.34 | 7 | 87,840 | 3100 | 4 |
| 47111 | 17-Aug-04 | 6.014 | 28.41 | 28 | 107,980 | 3800 | 4 |
| 47112 | 17-Aug-04 | 6.014 | 28.41 | 28 | 112,820 | 3970 | 4 |
| 47113 | HOLD | | | HOLD | - | | |

^{*}Concrete compressive strength by ASTM C 39

Types of Breaks











Cone

Cone & Split

Cone & Shear

Shear

Columnar

| Load | Ticket | Truck | Cubic Yds | Slump (inches) | Air Temp | Conc Temp | (%) Air Content | Time (min.) |
|------|--------|--------|-----------|-------------------|----------|-----------|--------------------|----------------|
| | Number | Number | | (inches) | (°F) | (°F) | Content | (min.) |
| | | | | | | | | |
| | | | | | | | | |
| | | | | - | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

Remarks:

Reinforcing steel was checked for size, grade, and spacing, and was found to be in general conformance

with project plan.

Checked by:

George S. Morrell, Supervisor