

R. W. Gillespie & Associates, Inc.

86 Industrial Park Road, Suite 4, Saco, ME 04072
200 International Drive, Suite 170, Portsmouth, NH 03801
ME 207-286-8008; Fax: 207-286-2882
NH 603-427-0244; Fax: 603-430-2041

LETTER OF TRANSMITTAL

Date:	09 Aug. 04	Project No.:	438-05
Attention:	Phillip Doughty, AIA (pdarch@maine.rr.com)		
Re:	New Jetways & Addition to Baggage Claim Portland, Maine		

Doughty & Associates, Inc.

362 U.S. Route 1

Falmouth, ME 04105

We are sending you attached In-Place Density Test Results.

Date(s) Performed: August 5, 2004

Test (s) Performed

In-Place Density Testing - Nuclear Method ASTM D2922



Meets Specification




Selected Tests Do Not Meet Specification - Noted with an *

Note: Materials descriptions and maximum laboratory dry density values were transmitted under separate cover and are referenced in the attached summaries by the material number.

Remarks:

Copy to: Roy Williams (rsw@ci.portland.me.us)

Signed:



SUMMARY OF IN-PLACE DENSITIES - ASTM D2922/D3017
 JETPORT BAGGAGE ADDITION
 PORTLAND, MAINE
 RWG&A PROJECT NO. 438-05

Client: Doughty & Associates, Inc.
 Test Date: August 5, 2004
 Technician: Michael Kramlich
 Gauge Model/Serial Number: Seamans L-500

Report Issue Date: **AUG 10 2004**

Lab No.	Soil Description	ASTM D1557 Max Density	ASTM D1557 Opt. Moisture
7250	4" Minus Gravel	136.0	7

Test No.	Location	Elevation (ft.)	ASTM D2922 Dry Density (pcf)	ASTM D3017 Water Content (%)	Percent of Max. (%)	Lab. No.
1	2'W of 51.9/1'S of W	55.5	129.5	5	95	7250
2	1'E of 51.9/W.5	55.5	129.6	4	95	7250
3	2'W of 51.9/1'S of W	56.5	134.1	4	99	7250
4	1'E of 51.9/W.5	56.5	129.5	4	95	7250
5	5'S of Y/1'W of 49.8	54.0	128.6	4	95	7250
6	2'S of Z/2'W of 49.8	54.0	130.3	3	96	7250
7	1'N of Z/18	54.0	135.7	3	100	7250
8	10'N of W/10'W of 51.9	54.5	129	4	95	7250
9	10'N of W/10'W of 51.9	55.5	133	4	97	7250
10	10'N of W/10'W of 51.9	56.5	130.0	4	96	7250

Remarks:

Checked by: 