

R. W. Gillespie & Associates, Inc.

Corporate Office

86 Industrial Park Rd., Ste. 4
Saco, ME 04072
Tel: 207-286-8008
Fax: 207-286-2882

P.O. Box 289
Augusta, ME 04332
Tel: 207-623-4914
Fax: 207-623-3429

200 Int'l. Dr., Ste. 170
Portsmouth, NH 03801
Tel: 603-427-0244
Fax: 603-430-2041

LETTER OF TRANSMITTAL

Date:	October 14, 2004	Project No.:	438-005
Attention:	Mr. Phillip Doughty (pdarch@maine.rr.com)		
Re:	New Jetways & Addition to Baggage Claim Laboratory Testing Portland, Maine		

Doughty & Associates, Inc.

362 U.S. Route One

Falmouth, Maine 04105

We are sending you: Enclosed Attached Under separate cover via _____ the following items:
 Copy of Invoice Copy of Documentation/Details for Invoice Copy of Letter Copies of Report

One copy of each ultrasonic inspection for September 16, 21, 24 and October 13, 2004.

These are transmitted: As Requested For Your Use For Approval For Review and Comment

Remarks:

Copy To: Roy Williams

Signed: _____

Suzan A. Bullock, S/R

Quality Assurance Labs Inc.

NON-DESTRUCTIVE TESTING AND INSPECTION SERVICES
80 PLEASANT AVENUE - SOUTH PORTLAND, MAINE 04106 - TEL: (207) 799-8911 - FAX: (207) 799-7251

October 13, 2004

R. W. GILLESPIE & ASSOCIATES, INC.
86 Industrial Park Road, Suite 4
Saco, ME 04072

RE: Portland Jetport Terminal Expansion
Portland, ME
QAL 04-621
Project# 438-05

ATTN: ROBERT GILLESPIE

This letter will serve as my report for ultrasonic inspection. On 09/16/04 inspection was performed on the following,

Inspected moment connections 32Y and 32X, both were rejected for lack of penetration.

If you have any questions please call me at 799-8911.

Sincerely,



DAVID L. PRATT JR.
LEVEL II CWI# 97100861

MTZ

Quality Assurance Labs Inc.

NON-DESTRUCTIVE TESTING AND INSPECTION SERVICES

80 PLEASANT AVENUE • SOUTH PORTLAND, MAINE 04106 • TEL: (207) 799-8911 • FAX: (207) 799-7251

October 13, 2004

R. W. GILLESPIE & ASSOCIATES, INC.
86 Industrial Park Road, Suite 4
Saco, ME 04072

RE: Portland Jetport Terminal Expansion
Portland, ME
QAL 04-621
Project# 438-05

ATTN: ROBERT GILLESPIE

This letter will serve as my report for ultrasonic inspection. On 09/21/04 inspection was performed on the following,

Inspected all moment connections (tops only) Y.1-W.1-27-38. X32, Y32, 35W.1, 35X, 38W.1, and 38Y were rejected for lack of penetration and porosity.

If you have any questions please call me at 799-8911.

Sincerely,



DAVID L. PRATT JR.
LEVEL II CWI# 97100861

MTG

Quality Assurance Labs Inc.

NON-DESTRUCTIVE TESTING AND INSPECTION SERVICES

80 PLEASANT AVENUE • SOUTH PORTLAND, MAINE 04106 • TEL: (207) 799-8911 • FAX: (207) 799-7251

October 13, 2004

R.W. GILLESPIE & ASSOCIATES, INC.
86 Industrial Park Road, Suite 4
Saco, ME 04072

RE: Portland Jetport Terminal Expansion
Portland, ME
QAL 04-621
Project# 438-05


ATTN: ROBERT GILLESPIE

This letter will serve as my report for ultrasonic inspection. On 09/24/04 inspection was performed on the following,

Inspected repaired moment connections (tops only) X32, Y32, 35W.1, 35X, 38W.1, and 38Y. These were repaired, re-inspected and found acceptable.

If you have any questions please call me at 799-8911.

Sincerely,



DAVID L. PRATT JR.
LEVEL II CWI# 97100861

MTG

Quality Assurance Labs Inc.NON-DESTRUCTIVE TESTING AND INSPECTION SERVICES
80 PLEASANT AVENUE • SOUTH PORTLAND, MAINE 04106 • TEL: (207) 799-8911 • FAX: (207) 798-7251

October 13, 2004

R. W. GILLESPIE & ASSOCIATES, INC.
86 Industrial Park Road, Suite 4
Saco, ME 04072RE: Portland Jetport Terminal Expansion
Portland, ME
QAL 04-621
Project# 438-05

ATTN: ROBERT GILLESPIE


This letter will serve as my report for ultrasonic inspection. On 10/13/04 inspection was performed on the following,

All moment connections (bottoms) W.1-Y.1-27-28 were inspected and found acceptable, except 35W.1 was rejected for porosity.

Moment connections (6) tops only W.1-X-38-47 were inspected and found acceptable, except 47W.1 was rejected for lack of penetration.

If you have any questions please call me at 799-8911.

Sincerely,


DAVID L. PRATT JR.
LEVEL II CWI# 97100861

MTG