Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/12/13

2 / E2.01 TYPICAL LEVEL (2ND & 3RD) FLOOR PLAN - ELECTRICAL
1/8"=1'-0"

1 / E2.01 1ST LEVEL FLOOR PLAN - ELECTRICAL
1/8"=1'-0"

GENERAL NOTES:

1. CONNECT ALL EXIT SIGNS AND EMERGENCY BATTERY PACKS AHEAD OF SWITCHING AND LIGHTING CONTROL PANEL. PROVIDE A DEDICATED NON-SWITCHED PHASE CONDUCTOR TO ALL BATTERY PACKS.
2. PROVIDE A DEDICATED NEUTRAL TO EACH DIMMING CIRCUIT.
3. PROVIDE BATTERY BACK-UP FOR LIGHTING FIXTURES SYMBOLS SHADED.
EXAMPLE: (●) EMERGENCY LIGHTING.

KEYNOTES:

1. ELEVATOR MOTOR. 30HP/208V/3Ø 200/3/150 FUSIBLE LOCKABLE DISC. 3#1/0,1#6G-1 1/2"C
2. ELEVATOR FAN/LIGHT. 30/2/15 FUSIBLE, LOCKABLE DISC.
3. FSD (FIRE SMOKE DAMPER). 120V
4. EXIST. CONDENSING UNIT TO BE RELOCATED. EXTEND EXIST. ELECTRICAL TO NEW LOCATION & CONNECT.

PROJECT

PORTLAND HILTON GARDEN INN ADDITION

LOCATION

PORTLAND
145 JETPORT BLVD
PORTLAND, MAINE 04102

ARCHITECT

hogan campis architecture
1425 DUTCH VALLEY PL STUDIO B ATLANTA GA 30324
404 685 8868 V 404 685 8878 F WWW.HCARCH.NET

STAMP

STATE OF MAINE
AND SCOTT
No.9310
REGISTERED
PROFESSIONAL ENGINEER

ISSUED FOR:	DATE:
REVIEW	
PRICING	JULY 20,2012
PERMITTING	JAN. 30,2013
CONSTRUCTION	

REVISIONS

THIS DRAWING IS THE PROPERTY OF THE SAFAIE LANDRY PARTNERSHIP, INC. AND SHALL NOT BE REPRODUCED IN WHOLE OR IN PART WITHOUT WRITTEN PERMISSION. IT SHALL BE LIMITED FOR USE BY THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN.

JOB NO.
0479.000

DRAWING TITLE

FLOOR PLANS - ELECTRICAL

SL PROJECT# 120503

THE SAFAIE LANDRY PARTNERSHIP, INC.
8300 Ameritrust Court | Nottoway, Ohio 43082

SHEET NO.
E2.01

1/29/2013 2:45:34 PM