

Inspection Services
Michael J. Nugent
Manager



Department of Urban Development
Joseph E. Gray, Jr.
Director

CITY OF PORTLAND

Brain Knox
The Widewaters Group
145 Kingspine Boulevard
Portland, Maine 04102
CBL: 029AA016

11/13/2000

Dear Mr. Knox,

After a site visit and walkthrough on Monday, November 13, 2000, the following items of concern were brought to your attention at our meeting in your office trailer.

All guest rooms shall have at least two receptacle outlets readily accessible to any occupants of each guest room pursuant to NEC 1999, ART: 210-60(a) & (b).

A reasonable working temperature at or about 45-50 degrees shall be maintained prior to and during installation of all wiring types, including NMC, MC and single conductors and cables, to prevent damage to the insulation of the cables or conductors, pursuant to NEC 1999, ART: 90-1 & ART: 110-11.

This office shall strictly enforce these code requirements. If you have any further questions feel free to contact me at 874-8694. Please see attached documents.

Thank you,

Michael A. Collins

Chief Electrical Inspector
City of Portland
Cc: Central file
Mike Nugent
Sam Hoffses