

... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road Poland
P.O. Box 154 Minot, ME
Poland, ME 04274
207-998-2551

Job Name : Hilton Garden Inn Addition Portland Jetport 2nd unit 201
Drawing : FP-02
Location : 145 Jetport Boulevard Portland
Remote Area : 2B
Contract : 053013-1
Data File : second floor pend unit 201-203.WXF

HYDRAULIC CALCULATIONS
for

Project name: Hilton Garden Inn Addition 2nd floor unit 201-203
Location: 145 Jetport Boulevard Portland
Drawing no: FP-02
Date: 10/15/13

Design

Remote area number: 2B
Remote area location: SECOND FLOOR UNIT 201-203
Occupancy classification: RESIDENTIAL / LIGHT HAZARD
Density: .1 - Gpm/SqFt
Area of application: 4 HEAD - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: RESIDENTIAL PENDENT
No. of sprinklers calculated: 4
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 204 - GPM @ 49 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 10/31/2013
Location: Test hydrant in front of addition entrance
Source: Portland Water District

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Road Poland / P.O. Box 154 Minot, ME / Pola
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine / City of Portland
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve (C)

High Tech Fire Protection
Hilton Garden Inn Addition Portland Jetport 2nd unit 201


Page 2
Date 10/15/13

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 80
C2 - Residual Flow : 1433

Demand:

D1 - Elevation : 7.796
D2 - System Flow : 103.103
D2 - System Pressure : 48.952
Hose (Demand) : 100
D3 - System Demand : 203.103
Safety Margin : 32.994



Fittings Used Summary

High Tech Fire Protection
Hilton Garden Inn Addition Portland Jetport 2nd unit 201

Page 3
Date 10/15/13

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Bvcb	B Fly Vic 705W	0	0	0	0	0	0	5	5	0	12	12	8	11	12	14	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
 Hilton Garden Inn Addition Portland Jetport 2nd unit 201

Page 4
 Date 10/15/13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.8	19.48	na	25.6	0.1	256	7.6
201	20.0	K = K @ EQ01	20.28	na	25.6			
206	20.0	K = K @ EQ01	20.56	na	25.78			
221	20.0	K = K @ EQ01	20.56	na	25.77			
226	20.0	K = K @ EQ01	20.84	na	25.95			
BA	20.0		23.27	na				
BB	20.0		23.58	na				
BC	20.0		25.71	na				
BD	20.0		30.82	na				
AJ	20.0		36.11	na				
AK	10.0		40.5	na				
AL	10.0		40.93	na				
AM	10.0		40.96	na				
TOW	10.0		42.07	na				
BOW	3.0		48.33	na				
BASE	0.0		49.69	na				
HOSE	0.0		49.8	na	100.0			
TEST	2.0		48.95	na				

The maximum velocity is 9.5 and it occurs in the pipe between nodes DP1 and EQ01

Final Calculations - Hazen-Williams

High Tech Fire Protection
 Hilton Garden Inn Addition Portland Jetport 2nd unit 201

Page 5
 Date 10/15/13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	25.60 25.6	1.049 120.0 0.2053	1T	5.0 0.0 0.0	1.000 5.000 6.000	19.482 -0.433 1.232			K Factor = 5.80 Vel = 9.50	
	0.0 25.60						20.281		K Factor = 5.68	
201 to 206	25.60 25.6	1.682 120.0 0.0207		0.0 0.0 0.0	13.750 0.0 13.750	20.281 0.0 0.284			K Factor @ node EQ01 Vel = 3.70	
206 to BA	25.78 51.38	1.682 120.0 0.0748	1T	9.9 0.0 0.0	26.300 9.900 36.200	20.565 0.0 2.707			K Factor @ node EQ01 Vel = 7.42	
	0.0 51.38						23.272		K Factor = 10.65	
221 to 226	25.77 25.77	1.682 120.0 0.0209		0.0 0.0 0.0	13.750 0.0 13.750	20.556 0.0 0.287			K Factor @ node EQ01 Vel = 3.72	
226 to BB	25.95 51.72	1.682 120.0 0.0757	1T	9.9 0.0 0.0	26.300 9.900 36.200	20.843 0.0 2.741			K Factor @ node EQ01 Vel = 7.47	
	0.0 51.72						23.584		K Factor = 10.65	
BA to BB	51.38 51.38	2.157 120.0 0.0223		0.0 0.0 0.0	14.000 0.0 14.000	23.272 0.0 0.312			Vel = 4.51	
BB to BC	51.72 103.1	2.157 120.0 0.0808	1T	12.307 0.0 0.0	14.000 12.307 26.307	23.584 0.0 2.125			Vel = 9.05	
BC to BD	0.0 103.1	2.157 120.0 0.0808	1T	12.307 0.0 0.0	51.000 12.307 63.307	25.709 0.0 5.115			Vel = 9.05	
BD to AJ	0.0 103.1	2.157 120.0 0.0808	1B 1V 1T 1Fsp	7.384 4.307 12.307 0.0	4.300 23.998 28.298 0.0	30.824 3.000 2.286 0.0			* Fixed loss = 3 Vel = 9.05	
AJ to AK	0.0 103.1	4.26 120.0 0.0029	1V	8.954 0.0 0.0	10.000 8.954 18.954	36.110 4.331 0.055			Vel = 2.32	
AK to AL	0.0 103.1	4.26 120.0 0.0029	5V	44.768 0.0 0.0	103.000 44.768 147.768	40.496 0.0 0.434			Vel = 2.32	
AL to AM	0.0 103.1	4.26 120.0 0.0030	1V	8.954 0.0 0.0	0.500 8.954 9.454	40.930 0.0 0.028			Vel = 2.32	
AM to TOW	0.0 103.1	4.26 120.0 0.0029	11V 2F	98.49 10.534 0.0	270.000 109.024 379.024	40.958 0.0 1.114			Vel = 2.32	
TOW to BOW	0.0 103.1	4.26 120.0 0.0029	1Bvc 1Fsp 1T	15.8 0.0 26.334	6.000 71.102 77.102	42.072 6.032 0.226			* Fixed loss = 3 Vel = 2.32	

Final Calculations - Hazen-Williams

High Tech Fire Protection
 Hilton Garden Inn Addition Portland Jetport 2nd unit 201

Page 6
 Date 10/15/13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
			1S	28.968					
BOW to BASE	0.0 103.1	4.26 120.0 0.0029	1G 1E	2.633 13.167 0.0	6.000 15.800 21.800	48.330 1.299 0.064		Vel = 2.32	
BASE to HOSE	0.0 103.1	6.16 140.0 0.0004	1G 2E 1T	4.304 40.168 43.037	200.000 87.509 287.509	49.693 0.0 0.105		Vel = 1.11	
HOSE to TEST	100.00 203.1	12.34 140.0 0.0	1G 1E 1T	9.377 42.195 93.767	300.000 145.339 445.339	49.798 -0.866 0.020		Qa = 100 Vel = 0.54	
	0.0 203.10					48.952		K Factor = 29.03	