

. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : ERIC DAWSON RESIDENCE
Building : 45 TIDE MILL ROAD
Location : PORTLAND, MAINE 04102
System : #1 AREA #1
Contract :
Data File : ERIC DAWSON RESIDENCE HC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - ERIC DAWSON RESIDENCE Date - 12/6/12
Location - PORTLAND, MAINE 04102
Building - 45 TIDE MILL ROAD System No. - #1 AREA #1
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MICHAEL NOBLIT Drawing No. - FP-2
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
OCCUPANCY - HOUSE

S Type of Calculation: (X)NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 14 Gpm System Type
Listed Pres. at Start Point - 10.1 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 14' x 14' () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 26'-3"Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 28.172 Psi Required 41.749 At Test
Summary C-Factor Used: Overhead 150 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Rated Cap. 45 Cap.
T Time of Test - @ Psi 45 Elev.
E Static (Psi) - Elev.
R Residual (Psi) - Other Well
Flow (Gpm) - Proof Flow Gpm
S Elevation -
P Location:
P
L Source of Information:
Y

Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
ERIC DAWSON RESIDENCE


Page 2
Date 12/6/12

Pump Data:

P1 - Pump Churn Pressure : 49.5
 P2 - Pump Rated Pressure : 45
 P2 - Pump Rated Flow : 45
 P3 - Pump Pressure @ Max Flow : 29.25
 P3 - Pump Max Flow : 68

Demand:

D1 - Elevation : 11.369
 D2 - System Flow : 28.1718
 D2 - System Pressure : 41.749
 Hose (Adj City) : _____
 Hose (Demand) : _____
 D3 - System Demand : 28.1718
 Safety Margin : 6.796



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
ERIC DAWSON RESIDENCE

Page 3
Date 12/6/12

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
ERIC DAWSON RESIDENCE

Page 4
Date 12/6/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	26.25	4.4	10.1	na	13.98	0.05	0.001	10.1
14	26.25		10.45	na				
13	18.166		14.37	na				
12	18.166		14.74	na				
102	26.25	4.4	10.4	na	14.19	0.05	0.001	10.1
11	26.25		10.76	na				
10	18.166		14.69	na				
9	18.166		15.13	na				
8	18.166		15.96	na				
7	18.166		18.88	na				
6	18.166		22.52	na				
5	18.166		23.81	na				
4	6.5		32.31	na				
3	6.5		33.99	na				
2	6.5		35.87	na				
1	0.0		41.5	na				
TEST	0.0		41.75	na				

The maximum velocity is 10.46 and it occurs in the pipe between nodes 4 and 3

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
ERIC DAWSON RESIDENCE

Page 5
Date 12/6/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
101 to 14	13.98	1.101 150 0.0351	1T 0.0	9.563 0.0 10.062	0.500 9.562 0.0	10.100 0.0 0.353	K Factor = 4.40 Vel = 4.71
14 to 13	0.0	1.101 150 0.0351	1E 0.0	3.825 0.0 11.908	8.083 3.825 0.418	10.453 3.501 0.418	Vel = 4.71
13 to 12	0.0	1.101 150 0.0351	1T 0.0	9.563 0.0 10.562	1.000 9.562 0.371	14.372 0.0 0.371	Vel = 4.71
12 to 8	0.0	1.101 150 0.0351	1T 1E 0.0	9.563 3.825 34.717	21.330 13.387 1.218	14.743 0.0 1.218	Vel = 4.71
	0.0 13.98					15.961	K Factor = 3.50
102 to 11	14.19	1.101 150 0.0361	1T 0.0	9.563 0.0 10.062	0.500 9.562 0.0	10.398 0.0 0.363	K Factor = 4.40 Vel = 4.78
11 to 10	0.0	1.101 150 0.0361	1E 0.0	3.825 0.0 11.908	8.083 3.825 0.430	10.761 3.501 0.430	Vel = 4.78
10 to 9	0.0	1.101 150 0.0360	1T 0.0	9.563 0.0 12.222	2.660 9.562 0.440	14.692 0.0 0.440	Vel = 4.78
9 to 8	0.0	1.101 150 0.0360		0.0 0.0 23.000	23.000 0.0 0.829	15.132 0.0 0.829	Vel = 4.78
8 to 7	13.98	1.101 150 0.1283	1T 0.0	9.563 0.0 22.728	13.166 9.562 2.915	15.961 0.0 2.915	Vel = 9.49
7 to 6	0.0	1.101 150 0.1282	1T 0.0	9.563 0.0 28.392	18.830 9.562 3.641	18.876 0.0 3.641	Vel = 9.49
6 to 5	0.0	1.101 150 0.1282	1T 0.0	9.563 0.0 10.062	0.500 9.562 1.290	22.517 0.0 1.290	Vel = 9.49
5 to 4	0.0	1.101 120 0.1937	1T 0.0	6.328 0.0 17.828	11.500 6.328 3.454	23.807 5.053 3.454	Vel = 9.49
4 to 3	0.0	1.049 120 0.2454	1T 0.0	5.0 0.0 6.830	1.830 5.000 1.676	32.314 0.0 1.676	Vel = 10.46
3 to 2	0.0	1.049 120 0.2452	1E 0.0	2.0 0.0 7.660	5.660 2.000 1.878	33.990 0.0 1.878	Vel = 10.46

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.
ERIC DAWSON RESIDENCE

Page 6
Date 12/6/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
2 to 1	0.0 28.17	1.049 120 0.2453	1S	5.0 0.0 0.0	6.500 5.000 11.500	35.868 2.815 2.821		Vel = 10.46	
1 to TEST	0.0 28.17	1.049 120 0.2450		0.0 0.0 0.0	1.000 0.0 1.000	41.504 0.0 0.245		Vel = 10.46	
	0.0 28.17					41.749		K Factor = 4.36	