
Freezer Drawing for City Line Dr Project

3 messages

Julia Raso <julia@abcorental.com>
To: "jmb@portlandmaine.gov" <jmb@portlandmaine.gov>

Tue, Jan 23, 2018 at 12:04 PM

Julia Raso

Assistant Property & Office Manager

Transport Leasing Corporation

Dumpsters R US

P. [978-409-2576](tel:978-409-2576)

F. [978-409-2246](tel:978-409-2246)

Email: Julia@abcorental.com



 **Freezer Dimensions.pptx**
41K

Jeanie Bourke <jmb@portlandmaine.gov>
To: Julia Raso <julia@abcorental.com>, "mark@abcorental.com" <mark@abcorental.com>

Tue, Jan 23, 2018 at 1:30 PM

Hi Mark and Julie,

In looking over the prefab freezer information, I have a couple of questions/comments:

1. What is the width of the of structure?
2. Per NFPA, the sprinkler system will need to be extended into this structure, please confirm.

Thanks,
Jeanie

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer
Team Leader

City of Portland

Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715
[Quoted text hidden]

Julia Raso <julia@abcorental.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>
Cc: Mark Sanborn <mark@abcorental.com>

Tue, Jan 23, 2018 at 2:45 PM

Good Afternoon Jeanie,

- 1) The width of the structure is 24 feet wide.
- 2) Yes, Eastern Fire will be installing a sprinkler in the structure.

Thank you,

Julia

Julia Raso

Assistant Property & Office Manager

Transport Leasing Corporation

Dumpsters R US

P. 978-409-2576

F. 978-409-2246

Email: Julia@abcorental.com



From: Jeanie Bourke [mailto:jmb@portlandmaine.gov]
Sent: Tuesday, January 23, 2018 1:30 PM
To: Julia Raso <julia@abcorental.com>; Mark Sanborn <mark@abcorental.com>
Subject: Re: Freezer Drawing for City Line Dr Project

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about

1/23/2018

City of Portland Mail - Freezer Drawing for City Line Dr Project

government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.