

FC901 Battery Calculations Worksheet
 ver. 1.3
 7-Feb-2012

Fixed Field	Enter Numbers Here
Calculated Field	Choose a value

Ref. No Transport Leasing
Submitted By Eastern Fire Services

FC901 Panel		Standby (A)	Alarm (A)
Main Board		0.178	0.203
Device Current Draw		0.0143	0.0143
NAC 1		0	
NAC 2		0	
Aux power (external)			
FCACity Tie	No		
FSD901 Remote Annun.	2	0.0012	0.0014

Devices	Qty			
HFP-11 / 8713				
HFPO-11 / 8710				
HFPT-11 / 8712				
OOHC941				
OOH941				
OH921	1	0.0003	0.0003	
OP921				
HI921				
FDCIO422				
HMS / 8700-S/D/M	9	0.0126	0.0126	
HTRI-S / 8702				
HTRI-D / 8703	1	0.0014	0.0014	
HTRI-R / 8704				
HZM / 8705				
HCP / 8706				
ILED / 8726				
Total	11	0.0143	0.0143	System OK

Total Current	0.1923	0.2173
----------------------	--------	--------

Standby Time	24	4.615
---------------------	----	-------

Alarm Time	5	0.018
AH required (no reserve)		4.633
Battery Reserve	125%	

AH Required (with reserve)	5.791635417	System OK
-----------------------------------	-------------	-----------