



J1 DEMOLITION PLAN
1/8"=1'-0"



A1 FLOOR PLAN
1/8"=1'-0"

NOTES:

- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- REMOVE EXISTING 1x4 & 1x3 FIXTURES AS INDICATED. RE-USE BRANCH CIRCUITS FOR NEW LIGHTING.
- LIGHTS TO BE CONTROLLED (SWITCHED) BY ANDOVER CONTROL SYSTEM. EACH BRANCH CIRCUIT TO BE CONTROLLED AS A SEPARATE ZONE AND BE WIRED SO THAT EVERY THIRD 4' SECTION TO SWITCH SEPARATELY TO ALLOW FOR THREE DIFFERENT LIGHT LEVELS.
- EXISTING EXIT SIGNS TO REMAIN AS IS.
- LIGHT FIXTURES SHOWN AS 4' TO SHOW SWITCHING CONFIGURATION AND CIRCUIT WIRING. COORDINATE WITH LIGHTING SUPPLIER FOR EXACT LENGTH AND CONFIGURATION OF FIXTURES.

KEYED NOTE:

- RE-USE CIRCUIT BREAKERS IN PANELBOARD HL1W-1 TO FEED NEW LIGHTS.
- RE-USE EXISTING EMERGENCY LIGHTING BRANCH IN OPEN OFFICE AREA TO FEED NEW EMERGENCY LIGHTS SHOWN. FIELD VERIFY THAT BRANCH CIRCUIT HAS CAPACITY FOR ADDITIONAL (1200 WATTS) LOAD.

0	ISSUED FOR CONSTRUCTION-PHASE 3	6-9-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
6-9-03

CURRENT ISSUE STATUS:	

SMRT ARCHITECTURE ENGINEERING PLANNING
SMRT
144 Fore Street/P.O. Box 618
Portland, Maine 04104
tel. (207) 772-3846
fax. (207) 772-1070

UNIMPROVED
H01 OPEN OFFICE RENOVATIONS
PORTLAND, ME.

PHASE 3-
ELECTRICAL PLAN

SHEET TITLE:	1/8"=1'-0"	DATE:	6-9-03
PROJECT MANAGER:	JLH	GRAPHIC SCALE:	0" 1"
JOB CAP/DRAWN:	RJL/JAC	A/E OF RECORD:	DJT
SMRT CAD FILE:	E-103-03051	SHEET No.	E-103
PROJECT No.	03051		