



2ND FLOOR PLAN (EAST) - PLUMBING
 1/8"=1'-0"

- LEGEND NOTES:**
 (APPLY THIS SHEET ONLY)
- EXISTING PLUMBING (SINK, WATER CONNECTIONS, ETC) SHALL BE DEMOLISHED IN THIS AREA. SEE DEMO DRAWINGS FOR ADDITIONAL DETAILS.
 - CONNECT 3/4" COLD WATER, 2" WASTE AND 2" VENT TO EXISTING IN THIS AREA OF LARGER OR EQUAL SIZE AND MAKE CW CONNECTION WITH SHUT-OFF VALVE. VERIFY EXACT TIE IN LOCATION PRIOR TO CONSTRUCTION.
 - ROUTE 1/2" CW AND CONNECT WITH SHUT OFF VALVE TO ICE MAKER AND PROVIDE IN RECESSED BOX BELOW COUNTER. COORDINATE EXACT CONNECTION LOCATION WITH EQUIPMENT AND ARCHITECT AND ROUTE DRAIN TO HUB DRAIN IN THIS AREA. PROVIDE BACK FLOW PREVENTER AS REQUIRED BY LOCAL AUTHORITY. BFP SHALL MEET ASSE 1022 IN ACCORDANCE WITH IPC 608.16.10.
 - PIPING IN THIS AREA SHALL BE ROUTED UP THROUGH SLAB. SEE ISLAND SINK DETAIL (2/P1.002) FOR ADDITIONAL INFORMATION.
 - PROVIDE HUB DRAIN BELOW COUNTER IN READILY ACCESSIBLE LOCATION. COORDINATE WITH MILLWORK CONTRACTOR TO ENSURE PROPER ACCESS TO DRAIN.
 - ROUTE 1/2" CW AND CONNECT WITH SHUT OFF VALVE TO COFFEE MAKER AND PROVIDE IN RECESSED BOX BELOW COUNTER AND COORDINATE EXACT PIPING ROUTING WITH ARCHITECT. PROVIDE BACK FLOW PREVENTER AS REQUIRED BY LOCAL AUTHORITY. BFP SHALL MEET ASSE 1022 IN ACCORDANCE WITH IPC 608.16.10.
 - REPLACE EXISTING FLUSH VALVES WITH BATTERY OPERATED SENSOR TYPE, SLOAN 62-8111 OR EQUAL FOR THE WATER CLOSETS AND SLOAN 62-8180 OR EQUAL FOR THE URINALS.
 - DEMO EXISTING LAVATORIES IN THIS AREA AND REPLACE WITH NEW FIXTURES AS NOTED AND SPECIFIED. ENSURE THAT ALL EXISTING PIPING IS USED AND IN WORKING CONDITION AND TERMINAL ALL WATER PIPING WITH WALL STOPS.

Date: 06.18.2017
 Description: ISSUE FOR PERMIT AND CONSTRUCTION

Seal / Signature

Project Name: Unum Workplace Transformation- Phase 1 (H02)
 Project Number: 59.6481.000
 Description: 2ND FLOOR PLAN (EAST) - PLUMBING