



**2 2ND FLOOR PLAN - PLUMBING**  
P2.102W 1/8" = 1'-0"

- LEGEND NOTES:**  
(APPLY THIS SHEET ONLY)
- ① CONNECT NEW SANITARY/WASTE, VENT AND COLD WATER LINES TO EXISTING SANITARY SEWER, VENT AND DOMESTIC WATER PIPING IN THIS AREA OF EQUAL OR GREATER SIZE. PROVIDE SHUTOFF VALVE WITH CW CONNECTION. VERIFY EXACT TIE IN LOCATION PRIOR TO CONSTRUCTION.
  - ② ROUTE 1/2" CW AND CONNECT WITH SHUT OFF VALVE TO ICE MAKER AND PROVIDE IN RECESSED BOX BELOW COUNTER. COORDINATE EXACT CONNECTION LOCATION WITH EQUIPMENT AND ARCHITECT AND ROUTE DRAIN TO HUB DRAIN IN THIS AREA. PROVIDE BACK FLOW PREVENTOR AS REQUIRED BY LOCAL AUTHORITY. BFP SHALL MEET ASSE 1022 IN ACCORDANCE WITH IPC 608.16.10.
  - ③ PROVIDE HUB DRAIN BELOW COUNTER IN READILY ACCESSIBLE LOCATION FOR ICE MAKER DRAIN. COORDINATE WITH MILLWORK CONTRACTOR TO ENSURE PROPER ACCESS TO DRAIN.
  - ④ ROUTE 1/2" CW AND CONNECT WITH SHUT OFF VALVE TO REFRIGERATOR. PROVIDE RECESSED BOX. COORDINATE EXACT CONNECTION LOCATION WITH EQUIPMENT AND ARCHITECT. PROVIDE BACK FLOW PREVENTOR AS REQUIRED BY LOCAL AUTHORITY.
  - ⑤ ROUTE 1/2" CW AND CONNECT WITH SHUT OFF VALVE TO COFFEE MAKER AND PROVIDE IN RECESSED BOX BELOW COUNTER AND COORDINATE EXACT PIPING ROUTING WITH ARCHITECT. PROVIDE BACK FLOW PREVENTOR AS REQUIRED BY LOCAL AUTHORITY. BFP SHALL MEET ASSE 1022 IN ACCORDANCE WITH IPC 608.16.10.
  - ⑥ DEMOLISH EXISTING DRINKING FOUNTAIN IN THIS LOCATION AND PROVIDE NEW ADA COMPLIANT DRINKING FOUNTAIN AS SPECIFIED ON SHEET P0.002. TIE NEW 3" W, 1 1/2" AND 1/2" CW TO EXISTING SANITARY SEWER, VENT AND DOMESTIC WATER LINES OF EQUAL SIZE OR GREATER. COORDINATE EXACT CONNECTIONS WITH EXISTING CONDITIONS.
  - ⑦ PIPING SHALL BE ON THE TENANT SIDE OF THE WALL AND NOT PENETRATE INTO THE STAIR WELL.

Date	Description
12.15.2017	ISSUE FOR PERMIT AND CONSTRUCTION

Seal / Signature

Project Name

**Unum Workplace Transformation - Phase 2 & 3 (HO2 & HO3)**

Project Number

**59.6481.003**

Description

**2ND FLOOR PLAN - PLUMBING**

Scale

**P2.102W**