


City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 2211 Congress St		Owner: UNUM		Phone:		Permit No: 980026	
Owner Address:		Lessee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name: Pollution Control Services		Address: 3 Mallison Falls Rd Windham,		Phone: ME 04062 892-0884		Permit Issued: JAN 16 1998	
Past Use: Office Bldgs		Proposed Use: Same		COST OF WORK: \$		PERMIT FEE: \$ 10.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	
Proposed Project Description: Remove One Underground Tank				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
				Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>			
Permit Taken By: Mary Gresik				Date Applied For: 13 January 1998			



1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: *LENNETHA GRONDI* ADDRESS: DATE: 13 January 1998 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

Zone: CBL: 215-B-002

Zoning Approval:

Special Zone or Reviews:

Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan maj minor mm

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:


Approved
 Approved with Conditions
 Denied

Date: _____

CEO DISTRICT

COMMENTS

4/28/98 Tank removed.



	Type	Inspection Record	Date
Foundation:	_____	_____	_____
Framing:	_____	_____	_____
Plumbing:	_____	_____	_____
Final:	_____	_____	_____
Other:	_____	_____	_____


FIRE CODE PERMIT REPORT

DATE: 1/13/58 ADDRESS: 2211 Conzettes St
 PERMIT TO: Pollution Control
 OWNER/CONTRACTOR: UNUM
 APPROVED DENIED

CONDITIONS OF APPROVAL/DENIAL

1. The boiler or furnace shall be protected by enclosing with one hour fire rated construction including fire doors and ceiling or by providing automatic extinguishment and smoke protected enclosure. Sprinkler piping serving not more than six sprinklers may be connected to a domestic water supply system having a capacity sufficient to provide a 0.15 gpm, per square foot of floor throughout the entire area. An indicating shut-off valve shall be installed in an accessible location between the sprinkler and the connection to the domestic water supply. Minimum pipe size shall be 3/4 inch copper or 1 inch steel. Maximum coverage area of a residential sprinkler is 144 square feet per sprinkler.
2. All required Fire Alarm Systems shall have the capability of "Zone Disconnect" via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
3. All remote annunciators shall have a visible "trouble" indicator along with the Fire Alarm "Zone" indicators.
4. Any Master Box connected to the Municipal Fire Alarm System shall have a supervised Municipal Disconnect Switch.
5. All Master Box locations shall be approved by the Fire Department Director of Communications. A Master Box shall be located so that the center of the box is five feet above finished floor.
6. All Master Box locations are required to have a locked box (knoxbox).
7. A fire alarm acceptance report shall be submitted to the Portland Fire Department.
8. All underground tank removal(s) and/or installation(s) shall be done in accordance with the Department of Environmental Regulations (Chapter 691).
9. No cutting of tanks on site. Cutting of tanks is to be done at an approved tank disposal site.
10. Fire Dispatcher must be at least 48 hours in advance of removal and/or transportation of tanks.
11. All above ground L/P storage tanks shall be located in accordance with NFPA 53 Standards.
12. Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.

13. All piping shall be protected from possible mechanical damage and vandalism.
14. A - 1" storm fire department connection is required.
15. Any new sprinkler construction over six sprinkler heads needs to have State Fire Marshal approval.
16. Any renovations of sprinkler systems over 20 sprinkler heads needs to have State Fire Marshal approval.
17. A sprinkler performance test shall be submitted to the Portland Fire Department after completion of sprinkler work.
18. State Fire Marshal approval is required for this project.



Lt. J. McDougall
Fire Prevention Officer
City of Portland

17 State House Station
Augusta, Maine 04333-0017
Attention: Tank Removal Notice
Telephone: (207) 287-3831

... removal was completed.

NOTICE OF INTENT TO ABANDON (REMOVE) AN UNDERGROUND OIL STORAGE FACILITY

FILED WITH THE DEPARTMENT OF ENVIRONMENTAL PROTECTION AND YOUR LOCAL FIRE DEPARTMENT AT THE TIME OF THE SCHEDULED REMOVAL.

PLEASE TYPE OR PRINT IN INK:

Name of Facility Owner: UNUM
Mailing Address: 2211 CONGRESS ST Telephone #: _____
City: PORTLAND State: MAINE Zip Code: 04101
Contact Person (name, address & telephone #): JOHN FOX 770-1880
Name of Facility: UNUM 40 #1 SERVICE OIL TANK Registration #: 3418
Facility Location (town & street): 2211 CONGRESS ST.

1. Identify the tanks at this location which are going to be removed:

Tank #	Tank Age	Tank Size (gallons)	Type of Product Stored
1	5	2500	GASOLINE
2			
3			

2. Directions to this facility (be specific):

3. Is or was the tank(s) used to store Class I liquids (e.g., gasoline, jet fuel)? Yes No
IF YES, REMOVAL OF THE TANK(S) MUST BE DONE UNDER THE DIRECTION OF A CERTIFIED TANK INSTALLER.

Tank Installer's Name: JEFF EATON Certification Number: #303 Signature: Jeff Eaton

4. Environmental site assessments are required for all tanks except those used for storing heating oil, not for resale, or for farm or residential motor fuel tanks under 1,100 gallons where the product is used on site. Site Assessor's Name and Address (if applicable):

5. Name and telephone number of contractor who will do the tank removal:
POLLUTION CONTROL SERVICES

6. Expected date of removal (month/day/year): 1/3/98
I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

Date: 17 December 97 Signature of owner or operator: John R. Fox
Printed Name and Title: John R. Fox, Project Manager
Mail original and yellow copy to DEP; pink copy to Fire department; retain gold copy.
RETURN POSTCARD AFTER TANK(S) HAS BEEN REMOVED