



. . . Fire Protection by Computer Design

DEAN & ALLYN, INC.
PO BOX 709
116 LEWISTON ROAD
GRAY, MAINE 04039
207-657-5646

Job Name : UNUM HO1 PC/PRINTER STORAGE ROOM
Building : HO1 ZONE 1 GRD FLOOR PC/PRINTER STORAGE
Location : PORTLAND, MAINE
System : Z1-EH.WX3
Contract : C121125
Data File : UNUM HO1 GROUND Z1-EH.WX3

Hydraulic Design Information Sheet

Name - UNUM HO1 IMPROVEMENTS/RENOVATIONS Date - 02/08/2013
 Location - PORTLAND, MAINE
 Building - HO1 ZONE 1 GRD FLOOR PC/PRINTER STORAGE System No. - Z1-EH.WX3
 Contractor - DEAN & ALLYN, INC. Contract No. - C121125
 Calculated By - T. CLARKE Drawing No. -
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 9'-4"
 Occupancy - PC/PRINTER STORAGE

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 (X) Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E

M	Area of Sprinkler Operation - 2500	System Type	Sprinkler/Nozzle
	Density - 0.20	(X) Wet	Make VIKING
D	Area Per Sprinkler - 96	() Dry	Model VK300
E	Elevation at Highest Outlet - 9'-4"	() Deluge	Size 1/2x1/2
S	Hose Allowance - Inside - 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance - 0	() Other	Temp.Rat.155F
G	Hose Allowance - Outside - 500		

N

Note CALC WITH BOOSTER PUMP-26.2 PSI CUSHION

Calculation Flow Required - 1414.8 Press Required - 32.7 AT TEST
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - SEPT. 2012		Cap. -
T	Time of Test -	Rated Cap.- 750	Elev.-
E	Static Press - 67	@ Press - 50	
R	Residual Press - 60	Elev. - 2	Well
	Flow - 1316		Proof Flow
S	Elevation - 2		

U

P Location - HYDRANT #5

P

L Source of Information - BY OWNER

Y

C	Commodity N/A	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

O

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G

E Horizontal Barriers Provided:

Fittings Used Summary

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 2
Date 02/08/2013

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Bvca	B Fly Vic 705						6	6	7		8	12	14	16	18	19					
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
H	45' Grvd-Vic Elbow #11	0	0	1	1.5	2	2	3	3	3.5	3.5	4.5	5	6.5	8.5	10	18	20	23	25	30
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Y	Mechanical Tee	2	4	5	6	8	10.5	12.5	15.5	0	22	0	0	0	0	0	0	0	0	0	0
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 3
Date 02/08/2013

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
601B	9.333	5.6	18.37	na	24.0	0.3	80	7.0
601A	9.75		19.17	na				
608B	9.333	5.6	11.76	na	19.2	0.3	64	7.0
608A	9.75		12.61	na				
622B	9.333	5.6	26.45	na	28.8	0.3	96	7.0
622A	9.75		27.65	na				
632B	9.333	5.6	26.45	na	28.8	0.3	96	7.0
632A	9.75		28.29	na				
601	9.75	K = K @ 601A	22.1	na	25.77			
602	9.75	K = K @ 601A	22.14	na	25.79			
603	9.75	K = K @ 601A	22.32	na	25.9			
604	9.75	K = K @ 601A	22.65	na	26.08			
605	9.75	K = K @ 601A	23.22	na	26.41			
606	9.75	K = K @ 601A	24.21	na	26.97			
607	9.75	K = K @ 601A	25.62	na	27.74			
608	9.75	K = K @ 608A	12.79	na	19.33			
609	9.75	K = K @ 608A	12.87	na	19.4			
610	9.75	K = K @ 608A	13.23	na	19.66			
611	9.75	K = K @ 608A	13.88	na	20.14			
612	9.75	K = K @ 608A	15.03	na	20.96			
613	9.75	K = K @ 608A	17.06	na	22.33			
614	9.75	K = K @ 608A	20.02	na	24.19			
615	9.75	K = K @ 601A	22.31	na	25.89			
616	9.75	K = K @ 601A	22.35	na	25.91			
617	9.75	K = K @ 601A	22.53	na	26.02			
618	9.75	K = K @ 601A	22.86	na	26.21			
619	9.75	K = K @ 601A	23.44	na	26.53			
620	9.75	K = K @ 601A	24.44	na	27.1			
621	9.75	K = K @ 601A	25.86	na	27.87			
622	9.75	K = K @ 622A	27.65	na	28.8			
623	9.75	K = K @ 622A	27.67	na	28.81			
624	9.75	K = K @ 622A	27.76	na	28.85			
625	9.75	K = K @ 622A	27.91	na	28.93			
626	9.75	K = K @ 622A	28.17	na	29.07			
627	9.75	K = K @ 622A	28.62	na	29.3			
628	9.75	K = K @ 622A	29.27	na	29.63			
629	9.75	K = K @ 622A	35.58	na	32.67			
630	9.75	K = K @ 622A	35.97	na	32.85			
631	9.75		37.14	na				
632	9.75	K = K @ 632A	35.66	na	32.33			
633	9.75	K = K @ 632A	36.04	na	32.5			
634	9.75	K = K @ 632A	35.69	na	32.35			
635	9.75	K = K @ 632A	36.07	na	32.52			
636	9.75		37.21	na				
666	9.75		38.8	na				
667	9.75		38.81	na				
668	9.75		38.85	na				
657	9.75		31.49	na				
658	9.75		31.51	na				
659	9.75		31.55	na				
660	9.75		31.78	na				
661	9.75		32.01	na				
662	9.75		32.36	na				
663	9.75		33.42	na				
664	9.75		33.87	na				
665	9.5		38.84	na				
673	9.5		40.11	na				

Flow Summary - Standard

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 4
Date 02/08/2013

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
678	9.5		42.29	na				
679	9.5		43.44	na				
680	9.75		46.78	na				
TR1	5.833		57.42	na				
BR1	2.0		61.48	na				
PO	2.0		62.54	na				
PI	2.0		45.48	na				
FF	1.0		50.87	na				
UG1	-7.0		57.95	na	500.0			
UG2	-7.0		60.89	na				
UG3	-7.0		62.06	na				
TEST	2.0		59.0	na				

The maximum velocity is 21.08 and it occurs in the pipe between nodes 614 and 659

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 5
Date 02/08/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
601B	24.00	1.049	1T	5.0	0.417	18.367			K Factor = 5.60	
to		120.0		0.0	5.000	-0.181				
601A	24.0	0.1824		0.0	5.417	0.988			Vel = 8.91	
	0.0									
	24.00					19.174			K Factor = 5.48	
608B	19.20	1.049	1E	2.0	1.583	11.755			K Factor = 5.60	
to		120.0	1T	5.0	7.000	-0.181				
608A	19.2	0.1207		0.0	8.583	1.036			Vel = 7.13	
	0.0									
	19.20					12.610			K Factor = 5.41	
622B	28.80	1.049	1T	5.0	0.417	26.449			K Factor = 5.60	
to		120.0		0.0	5.000	-0.181				
622A	28.8	0.2555		0.0	5.417	1.384			Vel = 10.69	
	0.0									
	28.80					27.652			K Factor = 5.48	
632B	28.80	1.049	1E	2.0	0.917	26.449			K Factor = 5.60	
to		120.0	1T	5.0	7.000	-0.181				
632A	28.8	0.2555		0.0	7.917	2.023			Vel = 10.69	
	0.0									
	28.80					28.291			K Factor = 5.41	
601	25.76	2.157		0.0	7.125	22.099			K Factor @ node 601A	
to		120.0		0.0	0.0	0.0				
602	25.76	0.0062		0.0	7.125	0.044			Vel = 2.26	
602	25.80	2.157		0.0	8.000	22.143			K Factor @ node 601A	
to		120.0		0.0	0.0	0.0				
603	51.56	0.0225		0.0	8.000	0.180			Vel = 4.53	
603	25.89	2.157		0.0	6.875	22.323			K Factor @ node 601A	
to		120.0		0.0	0.0	0.0				
604	77.45	0.0476		0.0	6.875	0.327			Vel = 6.80	
604	26.09	2.157		0.0	7.000	22.650			K Factor @ node 601A	
to		120.0		0.0	0.0	0.0				
605	103.54	0.0814		0.0	7.000	0.570			Vel = 9.09	
605	26.41	2.157		0.0	8.000	23.220			K Factor @ node 601A	
to		120.0		0.0	0.0	0.0				
606	129.95	0.1239		0.0	8.000	0.991			Vel = 11.41	
606	26.97	2.157		0.0	8.000	24.211			K Factor @ node 601A	
to		120.0		0.0	0.0	0.0				
607	156.92	0.1758		0.0	8.000	1.406			Vel = 13.78	
607	27.74	2.157	1T	12.307	12.438	25.617			K Factor @ node 601A	
to		120.0		0.0	12.307	0.0				
657	184.66	0.2375		0.0	24.745	5.876			Vel = 16.21	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 6
Date 02/08/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
	0.0 184.66					31.493	K Factor = 32.91
608 to 609	19.33	1.682 120.0	0.0	7.125	12.786	0.0	K Factor @ node 608A
609 to 610	19.33	0.0122	0.0	7.125	0.087		Vel = 2.79
609 to 610	19.40	1.682 120.0	0.0	8.000	12.873	0.0	K Factor @ node 608A
610 to 611	38.73	0.0444	0.0	8.000	0.355		Vel = 5.59
610 to 611	19.67	1.682 120.0	0.0	6.875	13.228	0.0	K Factor @ node 608A
611 to 612	58.4	0.0948	0.0	6.875	0.652		Vel = 8.43
611 to 612	20.14	1.682 120.0	0.0	7.000	13.880	0.0	K Factor @ node 608A
612 to 613	78.54	0.1639	0.0	7.000	1.147		Vel = 11.34
612 to 613	20.96	1.682 120.0	0.0	8.000	15.027	0.0	K Factor @ node 608A
613 to 614	99.5	0.2540	0.0	8.000	2.032		Vel = 14.37
613 to 614	22.33	1.682 120.0	0.0	8.000	17.059	0.0	K Factor @ node 608A
614 to 659	121.83	0.3695	0.0	8.000	2.956		Vel = 17.59
614 to 659	24.19	1.682 120.0	1T 9.9	12.438	20.015	0.0	K Factor @ node 608A
659	146.02	0.5165	0.0	22.338	11.537		Vel = 21.08
	0.0 146.02					31.552	K Factor = 26.00
615 to 616	25.89	2.157 120.0	0.0	7.125	22.308	0.0	K Factor @ node 601A
616 to 617	25.89	0.0063	0.0	7.125	0.045		Vel = 2.27
616 to 617	25.91	2.157 120.0	0.0	8.000	22.353	0.0	K Factor @ node 601A
617 to 618	51.8	0.0226	0.0	8.000	0.181		Vel = 4.55
617 to 618	26.02	2.157 120.0	0.0	6.875	22.534	0.0	K Factor @ node 601A
618 to 619	77.82	0.0480	0.0	6.875	0.330		Vel = 6.83
618 to 619	26.21	2.157 120.0	0.0	7.000	22.864	0.0	K Factor @ node 601A
619 to 620	104.03	0.0821	0.0	7.000	0.575		Vel = 9.13
619 to 620	26.53	2.157 120.0	0.0	8.000	23.439	0.0	K Factor @ node 601A
620 to 621	130.56	0.1250	0.0	8.000	1.000		Vel = 11.46
620 to 621	27.10	2.157 120.0	0.0	8.000	24.439	0.0	K Factor @ node 601A
621	157.66	0.1772	0.0	8.000	1.418		Vel = 13.84

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 7
Date 02/08/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
621 to 660	27.87 185.53	2.157 120.0 0.2395	1T 12.307 0.0 0.0	12.438 12.307 24.745	25.857 0.0 5.927		K Factor @ node 601A		
	0.0 185.53					31.784	K Factor = 32.91		
622 to 623	28.80 28.8	2.635 120.0 0.0029	0.0 0.0 0.0	7.125 0.0 7.125	27.652 0.0 0.021		K Factor @ node 622A	Vel = 1.69	
623 to 624	28.81 57.61	2.635 120.0 0.0104	0.0 0.0 0.0	8.000 0.0 8.000	27.673 0.0 0.083		K Factor @ node 622A	Vel = 3.39	
624 to 625	28.85 86.46	2.635 120.0 0.0220	0.0 0.0 0.0	6.875 0.0 6.875	27.756 0.0 0.151		K Factor @ node 622A	Vel = 5.09	
625 to 626	28.94 115.4	2.635 120.0 0.0376	0.0 0.0 0.0	7.000 0.0 7.000	27.907 0.0 0.263		K Factor @ node 622A	Vel = 6.79	
626 to 627	29.06 144.46	2.635 120.0 0.0569	0.0 0.0 0.0	8.000 0.0 8.000	28.170 0.0 0.455		K Factor @ node 622A	Vel = 8.50	
627 to 628	29.31 173.77	2.635 120.0 0.0801	0.0 0.0 0.0	8.000 0.0 8.000	28.625 0.0 0.641		K Factor @ node 622A	Vel = 10.22	
628 to 662	29.63 203.4	2.635 120.0 0.1071	1T 16.474 0.0 0.0	12.438 16.474 28.912	29.266 0.0 3.097		K Factor @ node 622A	Vel = 11.97	
	0.0 203.40					32.363	K Factor = 35.75		
629 to 630	32.67 32.67	1.682 120.0 0.0324	0.0 0.0 0.0	12.000 0.0 12.000	35.584 0.0 0.389		K Factor @ node 622A	Vel = 4.72	
630 to 631	32.85 65.52	1.682 120.0 0.1173	0.0 0.0 0.0	9.917 0.0 9.917	35.973 0.0 1.163		K Factor @ node 622A	Vel = 9.46	
631 to 666	0.0 65.52	1.682 120.0 0.1173	1T 9.9 0.0 0.0	4.333 9.900 14.233	37.136 0.0 1.669		K Factor @ node 622A	Vel = 9.46	
	0.0 65.52					38.805	K Factor = 10.52		
632 to 633	32.33 32.33	1.682 120.0 0.0318	0.0 0.0 0.0	12.000 0.0 12.000	35.656 0.0 0.381		K Factor @ node 632A	Vel = 4.67	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 8
Date 02/08/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
633 to 667	32.51 64.84	1.682 120.0 0.1150	1T 9.9 0.0	14.250 9.900 24.150	36.037 0.0 2.777		K Factor @ node 632A Vel = 9.36
	0.0 64.84				38.814		K Factor = 10.41
634 to 635	32.35 32.35	1.682 120.0 0.0318	0.0 0.0	12.000 0.0	35.689 0.0		K Factor @ node 632A Vel = 4.67
635 to 636	32.52 64.87	1.682 120.0 0.1151	0.0 0.0	9.917 0.0 9.917	36.071 0.0 1.141		K Factor @ node 632A Vel = 9.37
636 to 668	0.0 64.87	1.682 120.0 0.1151	1T 9.9 0.0	4.333 9.900 14.233	37.212 0.0 1.638		Vel = 9.37
	0.0 64.87				38.850		K Factor = 10.41
666 to 667	65.52 65.52	4.26 120.0 0.0012	0.0 0.0	7.625 0.0	38.805 0.0		Vel = 1.47
667 to 668	64.83 130.35	4.26 120.0 0.0045	0.0 0.0	8.000 0.0 8.000	38.814 0.0 0.036		Vel = 2.93
668 to 673	64.87 195.22	4.26 120.0 0.0096	2H 9.217 2I 18.434 1Y 28.968	63.792 56.619 120.411	38.850 0.108 1.153		Vel = 4.39
	0.0 195.22				40.111		K Factor = 30.82
657 to 658	184.66 184.66	4.26 120.0 0.0083	0.0 0.0	1.917 0.0	31.493 0.0		Vel = 4.16
658 to 659	0.0 184.66	4.26 120.0 0.0087	0.0 0.0	4.917 0.0	31.509 0.0		Vel = 4.16
659 to 660	146.02 330.68	4.26 120.0 0.0253	0.0 0.0	9.167 0.0 9.167	31.552 0.0 0.232		Vel = 7.44
660 to 661	185.52 516.2	4.26 120.0 0.0580	0.0 0.0	3.917 0.0 3.917	31.784 0.0 0.227		Vel = 11.62
661 to 662	0.0 516.2	4.26 120.0 0.0579	0.0 0.0	6.083 0.0 6.083	32.011 0.0 0.352		Vel = 11.62

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 9
Date 02/08/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
662 to 663	203.40 719.6	4.26 120.0 0.1069		9.917 0.0 9.917	32.363 0.0 1.060			Vel = 16.20	
663 to 664	0.0 719.6	4.26 120.0 0.1070		4.188 0.0 4.188	33.423 0.0 0.448			Vel = 16.20	
664 to 665	0.0 719.6	4.26 120.0 0.1069	2I 18.434 1H 4.608	22.458 23.042 45.500	33.871 0.108 4.865			Vel = 16.20	
665 to 673	0.0 719.6	4.26 120.0 0.1069		11.854 0.0 11.854	38.844 0.0 1.267			Vel = 16.20	
673 to 678	195.22 914.82	6.357 120.0 0.0237	1J 31.433	60.271 31.433 91.704	40.111 0.0 2.176			Vel = 9.25	
678 to 679	0.0 914.82	6.357 120.0 0.0237	1J 31.433	17.042 31.433 48.475	42.287 0.0 1.151			Vel = 9.25	
679 to 680	0.0 914.82	6.357 120.0 0.0237	1J 31.433 1Bvca 17.603 1Fsp 0.0 1S 40.235	14.229 89.271 103.500	43.438 0.892 2.455		* Fixed loss = 1	Vel = 9.25	
680 to TR1	0.0 914.82	6.357 120.0 0.0237	12I 150.881	225.833 150.881 376.714	46.785 1.696 8.940			Vel = 9.25	
TR1 to BR1	0.0 914.82	6.357 120.0 0.0237	1Fsp 0.0 1Bvca 17.603 1T 37.72	3.833 55.323 59.156	57.421 2.660 1.404		* Fixed loss = 1	Vel = 9.25	
BR1 to PO	0.0 914.82	6.357 120.0 0.0237	2I 25.147	19.479 25.147 44.626	61.485 0.0 1.059			Vel = 9.25	
	0.0 914.82				62.544			K Factor = 115.68	
System Demand Pressure					62.544				
Safety Margin					26.226				
Continuation Pressure					88.770				
Pressure @ Pump Outlet					88.770				
Pressure From Pump Curve					-43.290				
Pressure @ Pump Inlet					45.481				
PI to FF	0.0 914.82	6.357 120.0 0.0237	2I 25.147 1Zac 0.0	7.250 25.147 32.397	45.481 4.624 0.769		* Fixed loss = 4.191	Vel = 9.25	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 10
Date 02/08/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
FF	0.0	6.16	2E 40.168	90.667	50.874				
to		140.0	1T 43.037	83.205	3.465				
UG1	914.82	0.0208	0.0	173.872	3.615		Vel = 9.85		
UG1	500.00	8.27	2F 28.468	174.667	57.954		Qa = 500		
to		140.0	1G 6.326	90.148	0.0				
UG2	1414.82	0.0111	1T 55.354	264.815	2.940		Vel = 8.45		
UG2	0.0	8.27	1T 55.354	50.000	60.894				
to		140.0	0.0	55.354	0.0				
UG3	1414.82	0.0111	0.0	105.354	1.170		Vel = 8.45		
UG3	0.0	8.27	1T 55.354	13.167	62.064				
to		140.0	1G 6.326	61.680	-3.898				
TEST	1414.82	0.0111	0.0	74.847	0.831		Vel = 8.45		
	0.0								
	1414.82				58.997		K Factor = 184.20		

Water Supply Curve (C)

DEAN & ALLYN, INC.
UNUM HO1 PC/PRINTER STORAGE ROOM

Page 11
Date 02/08/2013

City Water Supply: C1 - Static Pressure : 67 C2 - Residual Pressure: 60 C2 - Residual Flow : 1316 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 61.110 A2 - Adj Resid : 50.08 @ 750 A3 - Adj Resid : 38.223 @ 1125	Pump Data: P1 - Pump Churn Pressure : 56 P2 - Pump Rated Pressure : 50 P2 - Pump Rated Flow : 750 P3 - Pump Pressure @ Max Flow : 32.5 P3 - Pump Max Flow : 1125 City Residual Flow @ 0 = 4461.84 City Residual Flow @ 20 = 3683.69 City Water @ 150% of Pump = 61.76	Demand: D1 - Elevation : 3.357 D2 - System Flow : 914.82 D2 - System Pressure : 62.544 Hose (Demand) : D3 - System Demand : 914.82 Hose (Adj City) : 500 Safety Margin : 26.226
---	--	---

