



HEAD LEGEND

- 66 RELIABLE MODEL FIFR56 RECESS PENDENT
155' QUICK RESPONSE, STANDARD COVERAGE
K=5.6, 1/2" NPT, SIN RA1425
- 27 RELIABLE MODEL J112 EGLH WHITE PENDENT
155' QUICK RESPONSE, EXTENDED COVERAGE (18X18)
K=11.2, 3/4" NPT, SIN RA7216
- 6 RELIABLE MODEL FIFR56 BRASS UPRIGHT
155' QUICK RESPONSE, STANDARD COVERAGE
K=5.6, 1/2" NPT, SIN RA1425
- ▽ 1 RELIABLE MODEL FIFR56 BRASS HSU
155' QUICK RESPONSE, STANDARD COVERAGE

	DANA A. STEWART NICET IV - #064544
APPROVED BY: _____ DATE: _____ CHECKED BY: _____ DATE: _____ AT DEAN & ALLYN, INC SCALE AS NOTED SHEET NO. 3 OF 4	DRAWING TITLE: SPRINKLER LAYOUT PARTIAL FIRST FLOOR JOB: 2014 UNUM-HOI Interior Renovations PORTLAND, MAINE CONTRACT WITH: Consigli Construction
SUBMIT FOR APPROVAL 2/19/15 REVISIONS DATE	NO. OF SPRINKLERS SHOWN ON THIS SHEET: 100 NO. OF SPRINKLERS ON JOB: 164 CONTRACT NO.: C151248