



... Fire Protection by Computer Design

Dean and Allyn Inc
116 Lewiston Road
Gray ME, 04039
(207)657-5646

Job Name : UNUM FIRST
Building : HO-1 FIRST FLOOR
Location : PORTLAND
System : 1
Contract : C151248
Data File : C1248 1ST.WXF

Hydraulic Design Information Sheet

Name - UNUM HO-1 Date - 2/20/15
 Location - PORTLAND
 Building - HO-1 FIRST FLOOR System No. - 1
 Contractor - DEAN AND ALLYN INC Contract No. - C151248
 Calculated By - S. COTE Drawing No. - 2 OF 4
 Construction: () Combustible () Non-Combustible Ceiling Height - 15'
 Occupancy - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 930	System Type	Sprinkler/Nozzle
	Density	- .10	(X) Wet	Make RELIABLE
D	Area Per Sprinkler	- 256	() Dry	Model J112
E	Elevation at Highest Outlet	- 15'	() Deluge	Size 3/4"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 11.2
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 480.107 Press Required - 40.118
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - SEPT. 2012		Cap. -
T	Time of Test -	Rated Cap.- 750	Elev.-
E	Static Press - 67	@ Press - 50	
R	Residual Press - 60	Elev. - 2	Well
	Flow - 1316		Proof Flow
S	Elevation - 2		

P Location - HYDRANT #5

L Source of Information - BY OWNER

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:

Fittings Used Summary

Dean and Allyn Inc
UNUM FIRST

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Bvca	B Fly Vic 705						6	6	7		8	12	14	16	18	19						
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
Fha *	½ in FlexHead - 2 Ft Long	0	0	11					0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Dean and Allyn Inc
UNUM FIRST

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
10A	138.0	5.6	10.41	na	18.07	0.1	136	7.0
11A	138.0	5.6	11.03	na	18.6	0.1	186	7.0
12A	138.0	5.6	15.35	na	21.94	0.1	186	7.0
13A	138.0	11.2	8.1	na	31.87	0.1	181	7.0
14A	138.0	11.2	9.6	na	34.7	0.1	256	7.2
15A	138.0	11.2	16.14	na	44.99	0.1	181	7.2
16A	138.0	11.2	18.51	na	48.18	0.1	256	7.2
17A	138.0	11.2	14.18	na	42.18	0.1	256	7.2
18A	132.333	5.6	30.59	na	30.97	0.1	140	7.0
19A	132.333	11.2	21.13	na	51.48	0.1	227	7.2
20A	132.333	5.6	43.94	na	37.12	0.1	144	7.0
10	139.0		11.96	na				
11	139.0		13.24	na				
12	139.0		17.73	na				
100	139.0		18.74	na				
13	139.0		13.74	na				
14	139.0		17.46	na				
15	139.0		27.19	na				
16	139.0		34.24	na				
101	139.0		22.08	na				
17	139.0		25.65	na				
18	133.334		36.36	na				
103	139.0		42.79	na				
104	133.334		47.33	na				
19	133.334		34.35	na				
19.1	133.334		46.32	na				
19.2	133.334		57.97	na				
20	133.334		50.7	na				
20.1	133.334		55.61	na				
20.2	133.334		57.99	na				
107	133.334		58.79	na				
106	133.334		58.82	na				
105	133.334		53.43	na				
102	133.334		53.85	na				
110	134.5		58.71	na				
111	134.5		65.52	na				
112	134.5		77.73	na				
113	118.5		84.82	na				
114	117.583		85.57	na				
115	118.5		85.53	na				
TR	113.833		88.3	na				
BR	110.0		91.24	na				
PO	110.0		91.44	na				
PI	110.0		61.31	na				
FF	109.0		64.54	na				
UG1	101.0		68.71	na	100.0			
UG2	101.0		69.11	na				
UG3	101.0		69.27	na				
TEST	109.0		65.92	na				

The maximum velocity is 22.36 and it occurs in the pipe between nodes 110 and 111

Final Calculations - Hazen-Williams

Dean and Allyn Inc
UNUM FIRST

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
10A to 10	18.07 18.07	1.049 120.0 0.1079	Fha 2E	11.0 4.0 0.0	3.375 15.000 18.375	10.414 -0.433 1.982			K Factor = 5.60 Vel = 6.71	
	0.0 18.07						11.963		K Factor = 5.22	
11A to 11	18.60 18.6	1.049 120.0 0.1138	Fha 2E T	11.0 4.0 5.0	3.250 20.000 23.250	11.032 -0.433 2.645			K Factor = 5.60 Vel = 6.90	
	0.0 18.60						13.244		K Factor = 5.11	
12A to 12	21.94 21.94	1.049 120.0 0.1544	Fha 2E	11.0 4.0 0.0	3.250 15.000 18.250	15.348 -0.433 2.818			K Factor = 5.60 Vel = 8.14	
	0.0 21.94						17.733		K Factor = 5.21	
13A to 13	31.88 31.88	1.049 120.0 0.3083	Fha 2E	11.0 4.0 0.0	4.708 15.000 19.708	8.099 -0.433 6.075			K Factor = 11.20 Vel = 11.83	
	0.0 31.88						13.741		K Factor = 8.60	
14A to 14	34.70 34.7	1.049 120.0 0.3607	Fha E T	11.0 2.0 5.0	5.000 18.000 23.000	9.601 -0.433 8.297			K Factor = 11.20 Vel = 12.88	
	0.0 34.70						17.465		K Factor = 8.30	
15A to 15	44.99 44.99	1.049 120.0 0.5831	Fha 2E	11.0 4.0 0.0	4.708 15.000 19.708	16.135 -0.433 11.491			K Factor = 11.20 Vel = 16.70	
	0.0 44.99						27.193		K Factor = 8.63	
16A to 16	48.18 48.18	1.049 120.0 0.6620	Fha E T	11.0 2.0 5.0	6.416 18.000 24.416	18.508 -0.433 16.163			K Factor = 11.20 Vel = 17.89	
	0.0 48.18						34.238		K Factor = 8.23	
17A to 17	42.18 42.18	1.049 120.0 0.5174	Fha E T	11.0 2.0 5.0	5.000 18.000 23.000	14.180 -0.433 11.901			K Factor = 11.20 Vel = 15.66	
	0.0 42.18						25.648		K Factor = 8.33	
18A to 18	30.97 30.97	1.049 120.0 0.2923	Fha E T	11.0 2.0 5.0	3.250 18.000 21.250	30.588 -0.434 6.211			K Factor = 5.60 Vel = 11.50	
	0.0 30.97						36.365		K Factor = 5.14	
19A to 19	51.48 51.48	1.049 120.0 0.7482	Fha 2E	11.0 4.0 0.0	3.250 15.000 18.250	21.126 -0.434 13.655			K Factor = 11.20 Vel = 19.11	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
UNUM FIRST

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 51.48						34.347		K Factor = 8.78	
20A to 20	37.12 37.12	1.049 120.0 0.4086	Fha 2E	11.0 4.0 0.0	2.625 15.000 17.625	43.938 -0.434 7.201			K Factor = 5.60	
	0.0 37.12						50.705		K Factor = 5.21	
10 to 11	18.07 18.07	1.049 120.0 0.1079		0.0 0.0 0.0	11.875 0.0 11.875	11.963 0.0 1.281			Vel = 6.71	
11 to 100	18.60 36.67	1.049 120.0 0.3995	T	5.0 0.0 0.0	8.750 5.000 13.750	13.244 0.0 5.493			Vel = 13.61	
	0.0 36.67						18.737		K Factor = 8.47	
12 to 100	21.94 21.94	1.049 120.0 0.1545	T	5.0 0.0 0.0	1.500 5.000 6.500	17.733 0.0 1.004			Vel = 8.14	
100 to 101	36.67 58.61	1.38 120.0 0.2502	T	6.0 0.0 0.0	7.375 6.000 13.375	18.737 0.0 3.346			Vel = 12.57	
	0.0 58.61						22.083		K Factor = 12.47	
13 to 14	31.88 31.88	1.049 120.0 0.3082		0.0 0.0 0.0	12.083 0.0 12.083	13.741 0.0 3.724			Vel = 11.83	
14 to 101	34.70 66.58	1.38 120.0 0.3167	T	6.0 0.0 0.0	8.583 6.000 14.583	17.465 0.0 4.618			Vel = 14.28	
	0.0 66.58						22.083		K Factor = 14.17	
15 to 16	44.99 44.99	1.049 120.0 0.5831		0.0 0.0 0.0	12.083 0.0 12.083	27.193 0.0 7.045			Vel = 16.70	
16 to 103	48.18 93.17	1.38 120.0 0.5897	T	6.0 0.0 0.0	8.500 6.000 14.500	34.238 0.0 8.550			Vel = 19.99	
	0.0 93.17						42.788		K Factor = 14.24	
101 to 17	125.19 125.19	1.61 120.0 0.4807		0.0 0.0 0.0	7.416 0.0 7.416	22.083 0.0 3.565			Vel = 19.73	
17 to 18	42.17 167.36	2.067 120.0 0.2436	3E	15.0 0.0 0.0	18.916 15.000 33.916	25.648 2.454 8.263			Vel = 16.00	
18 to 102	30.98 198.34	2.067 120.0 0.3335	T	10.0 0.0 0.0	42.416 10.000 52.416	36.365 0.0 17.482			Vel = 18.96	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
UNUM FIRST

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 198.34									
						53.847			K Factor = 27.03	
103 to 104	93.17	1.61 120.0		0.0	7.500	42.788				
				0.0	0.0	2.454				
	93.17	0.2784		0.0	7.500	2.088			Vel = 14.68	
104 to 105	0.0	2.067 120.0	T	10.0	64.000	47.330				
				0.0	10.000	0.0				
	93.17	0.0824		0.0	74.000	6.100			Vel = 8.91	
	0.0 93.17									
						53.430			K Factor = 12.75	
19 to 19.1	51.48	1.049 120.0		0.0	16.000	34.347				
				0.0	0.0	0.0				
	51.48	0.7481		0.0	16.000	11.970			Vel = 19.11	
19.1 to 19.2	0.0	1.38 120.0	Eq	27.208	32.000	46.317				
				0.0	27.208	0.0				
	51.48	0.1968		0.0	59.208	11.651			Vel = 11.04	
19.2 to 106	0.0	1.61 120.0	T	8.0	1.208	57.968				
				0.0	8.000	0.0				
	51.48	0.0929		0.0	9.208	0.855			Vel = 8.11	
	0.0 51.48									
						58.823			K Factor = 6.71	
20 to 20.1	37.12	1.049 120.0		0.0	12.000	50.705				
				0.0	0.0	0.0				
	37.12	0.4086		0.0	12.000	4.903			Vel = 13.78	
20.1 to 20.2	0.0	1.38 120.0		0.0	22.166	55.608				
				0.0	0.0	0.0				
	37.12	0.1074		0.0	22.166	2.381			Vel = 7.96	
20.2 to 107	0.0	1.61 120.0	T	8.0	7.875	57.989				
				0.0	8.000	0.0				
	37.12	0.0507		0.0	15.875	0.805			Vel = 5.85	
107 to 106	0.0	2.635 120.0		0.0	6.166	58.794				
				0.0	0.0	0.0				
	37.12	0.0047		0.0	6.166	0.029			Vel = 2.18	
106 to 110	51.48	2.635 120.0	T	16.474	0.708	58.823				
				0.0	16.474	-0.505				
	88.6	0.0230		0.0	17.182	0.396			Vel = 5.21	
	0.0 88.60									
						58.714			K Factor = 11.56	
105 to 102	93.17	2.635 120.0		0.0	16.500	53.430				
				0.0	0.0	0.0				
	93.17	0.0253		0.0	16.500	0.417			Vel = 5.48	
102 to 110	198.34	2.635 120.0	T	16.474	9.291	53.847				
				0.0	16.474	-0.505				
	291.51	0.2085		0.0	25.765	5.372			Vel = 17.15	
110 to 111	88.60	2.635 120.0	T	16.474	3.500	58.714				
				0.0	16.474	0.0				
	380.11	0.3406		0.0	19.974	6.803			Vel = 22.36	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
UNUM FIRST

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
111 to 112	0.0 380.11	2.635 120.0 0.3406	T Bvca Fsp	16.474 8.237 0.0	2.333 24.711 27.044	65.517 3.000 9.212			** Fixed Loss = 3 Vel = 22.36	
112 to 113	0.0 380.11	6.357 120.0 0.0047	E	17.603 0.0 0.0	16.000 17.603 33.603	77.729 6.930 0.157			Vel = 3.84	
113 to 114	0.0 380.11	6.357 120.0 0.0047	2E	35.205 0.0 0.0	41.041 35.205 76.246	84.816 0.397 0.356			Vel = 3.84	
114 to 115	0.0 380.11	6.357 120.0 0.0047	2E	35.205 0.0 0.0	41.000 35.205 76.205	85.569 -0.397 0.356			Vel = 3.84	
115 to TR	0.0 380.11	6.357 120.0 0.0047	E	17.603 0.0 0.0	142.750 17.603 160.353	85.528 2.021 0.750			Vel = 3.84	
TR to BR	0.0 380.11	6.357 120.0 0.0047	Fsp Bvca T	0.0 17.603 37.72	3.833 55.323 59.156	88.299 2.660 0.276			** Fixed Loss = 1 Vel = 3.84	
BR to PO	0.0 380.11	6.357 120.0 0.0047	2I	25.147 0.0 0.0	19.479 25.147 44.626	91.235 0.0 0.209			Vel = 3.84	
	0.0 380.11					91.444			K Factor = 39.75	
						91.444				
						25.798				
						117.242				
						117.242				
						-55.932				
						61.310				
PI to FF	0.0 380.11	6.357 120.0 0.0047	2I Zac	25.147 0.0 0.0	7.250 25.147 32.397	61.310 3.073 0.152			** Fixed Loss = 2.64 Vel = 3.84	
FF to UG1	0.0 380.11	6.16 140.0 0.0041	2E T	40.168 43.037 0.0	90.667 83.205 173.872	64.535 3.465 0.712			Vel = 4.09	
UG1 to UG2	100.00 480.11	8.27 140.0 0.0015	2F G T	28.468 6.326 55.354	174.667 90.148 264.815	68.712 0.0 0.398			Qa = 100 Vel = 2.87	
UG2 to UG3	0.0 480.11	8.27 140.0 0.0015	T	55.354 0.0 0.0	50.000 55.354 105.354	69.110 0.0 0.158			Vel = 2.87	
UG3 to TEST	0.0 480.11	8.27 140.0 0.0015	T G	55.354 6.326 0.0	13.167 61.680 74.847	69.268 -3.465 0.113			Vel = 2.87	
	0.0 480.11					65.916			K Factor = 59.14	

Water Supply Curve C

Dean and Allyn Inc
UNUM FIRST

Page 8
Date

City Water Supply: C1 - Static Pressure : 67 C2 - Residual Pressure: 60 C2 - Residual Flow : 1316 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 62.471 A2 - Adj Resid : 54.897 @ 750 A3 - Adj Resid : 44.598 @ 1125	Pump Data: P1 - Pump Churn Pressure : 56 P2 - Pump Rated Pressure : 50 P2 - Pump Rated Flow : 750 P3 - Pump Pressure @ Max Flow : 32.5 P3 - Pump Max Flow : 1125 City Residual Flow @ 0 = 4461.84 City Residual Flow @ 20 = 3683.69 City Water @ 150% of Pump = 61.76	Demand: D1 - Elevation : 12.560 D2 - System Flow : 380.107 D2 - System Pressure : 91.444 Hose (Demand) : _____ D3 - System Demand : 380.107 Hose (Adj City) : 100 Safety Margin : 25.798
--	--	--

