## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

UNUM CORP

Located at

2211 CONGRESS ST

**PERMIT ID:** 2015-00443

**ISSUE DATE:** 04/14/2015

CBL: 215 B002001

has permission to For the installation of a Water-Based Fire Suppression System - extension of

existing systeem to areas on the First Floor ("UNUM Corp.").

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

**Building Official** 

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

## Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 8	74-8716	2015-00443	03/11/2015	215 B002001
Proposed Use:	Proposed	<b>Project Description:</b>		
Same: Offices - UNUM Corp.		on of existing syst	Vater-Based Fire Sup eem to areas on the F	•
Dept: Zoning Status: Approved Ronditions:  1) This a	eviewer:	Tammy Munson	Approval Da	nte: 03/18/2015 Ok to Issue: ✓
Dept: Fire Status: Approved w/Conditions Ronote: Conditions:  1) System acceptance and commissioning must be coordinated with		Craig Messinger		Ok to Issue: 🗹

- Fire Department. Call 874-8400 to schedule.
- 2) The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition.
- 3) Shall comply with NFPA 13
- 4) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 5) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 6) All construction shall comply with City Code Chapter 10.

**PERMIT ID:** 2015-00443 Located at: 2211 CONGRESS ST CBL: 215 B002001