



PLAN NORTH
SECOND FLOOR DEVICE PLACEMENT PLAN-WEST
 SCALE: 1/8" = 1'-0"
 0 4 8 16
 (IN FEET)

GENERAL NOTES:
 1. COORDINATE ALL DEVICES LOCATION AND MOUNTING HEIGHTS WITH THE ARCHITECT & FURNITURE VENDOR PRIOR TO INSTALLATION.
 2. HATCHED AREA NOT IN THE SCOPE OF WORK.
 3. 'R' DENOTES EXISTING DEVICES TO REMAIN. 'R' DENOTES EXISTING DEVICES TO BE RELOCATED. 'D' DENOTES EXISTING ITEM TO BE REMOVED.
 4. VERIFY PROPER FUNCTIONALITY OF ALL EXISTING AND RELOCATED FIRE ALARM DEVICES, INCLUDING THEIR HOUSING, LENSES, ETC., OPERATING AS INTENDED OR HAVE ABOVE NORMAL WEAR OR DEFECTS.
 5. ALL WIRING WITHIN AND THROUGH THE OPEN TO STRUCTURE AREAS SHALL BE IN EMT.
REMARKS:
 ◊ EXISTING DEVICE TO BE RELOCATED INTO NEW CEILING. EXTEND ALL ASSOCIATED CONDUIT AND WIRING AS REQUIRED.

tyco
 SimplexGrinnell
 Safer. Smarter. Tyco.SM
 DISTRICT - ME
 31 THOMAS DRIVE
 SUSTONVILLE, VT 05488
 PHONE: 802.887.5011
 FAX: 802.887.5012

unum

UNUM WORKPLACE TRANSFORMATION - HO2
 UNUM HO2
 2211 CONGRESS ST, MAIL STOP B146
 PORTLAND, ME 04102-1941

DATE	BY	CHK	DESCRIPTION

DRAWN BY: PRANESH
 CHECKED BY: AO
 ISSUE DATE: 11/3/17
 JOB #: 602887501
 PROJECT #: 147
 SIMPLEXPGRINNELL © 2017
 SYSTEM:
 FIRE ALARM SYSTEM
 SHEET:
 SECOND FLOOR DEVICE PLACEMENT PLAN-WEST