RISER NOTES:

1. RISER IS A DIAGRAMMATICAL REPRESENTATION OF THE SYSTEM ARCHITECTURE. IT IS NOT INTENDED TO REPRESENT ACTUAL WIRE RUNS OR PANEL PENETRATIONS. REFER TO FLOOR PLANS AND PANEL DETAILS FOR CIRCUIT ROUTING INFORMATION.
2. ALL WIRING SHALL COMPLY WITH NFPA 70 ARTICLE 760 POWER LIMITED SYSTEMS. SEE FA –002 FOR WIRE SCHEDULE

tyco SimplexGrinnell
Safer. Smarter. Tyco.™
DISTRICT: 147
30 TUTTLE DRIVE
WESTBROOK ME 04092
SERVICE: 207-842-8440
PHONE: 207-842-8440
FAX: 207-842-8439

unum

UNUM WORKPLACE TRANSFORMATION - HO2

UNUM HO2
2211 CONGRESS ST, MAIL STOP B146
PORTLAND, ME 04102-1941

ISSUE LOG				
MARK	DATE	CAD	CHK	DESCRIPTION

Revisions shown with Δ revisions

DRAWN BY:	PRANESH
CHECKED BY:	AO
ISSUE DATE:	11/3/17
JOB #:	602887501
PROJECT #:	147:
SIMPLEXGRINNELL ©	2017

SYSTEM: FIRE ALARM SYSTEM

SHEET: RISER DIAGRAM - SECOND FLOOR

FA-202

IMPORTANT NOTICE TO USERS: By accepting or using this drawing and/or the information contained herein, the user agrees to the following terms and conditions: The electronic information in the drawing may be subject to intentional or unintentional alteration. Any use, reuse, copying modification or alteration of the information contained herein shall be at the sole risk of the user. This information may not be sold or transferred to any third party. SimplexGrinnell disclaims all liability for the use or reuse of altered files by the user or any third party and such use will be a user's sole risk. User shall, to the fullest extent permitted by law, defend, indemnify, and hold SimplexGrinnell harmless from any and all claims for bodily injury and/or property damage or loss arising out of or in connection with such use.

FILE PATH: C:\Users\sechapman\Box Sync\Current Projects\147-602887501 - Unum HO2 FA Devices\Fire Alarm\FA-201.dwg
LAST SAVED BY: SECHAPMAN
LAST PRINTED: 11/3/2017 12:43:09 PM
30" x 42" - Arch E1 Size