



**... Fire Protection by Computer Design**

Dean and Allyn, Inc.  
116 Lewiston Rd  
Gray, ME 04039  
(207) 657-5646

Job Name : Unum  
Drawing : FP-04  
Location : 2211 Congress St. Portland, ME 04122  
Remote Area : 1  
Contract : C171470  
Data File : Unum C171470.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Unum HO 2 Restack and Consolidation  
**Location:** 2211 Congress St. Portland, ME 04122  
**Drawing no:** FP-04  
**Date:** 11/20/17

**Design**

**Remote area number:** 1  
**Remote area location:** 2nd Floor West Open Collab 2.2.C.303  
**Occupancy classification:** Light Hazard  
**Density:** .1 - Gpm/SqFt  
**Area of application:** 1002 - SqFt  
**Coverage per sprinkler:** 225 - SqFt  
**Type of sprinklers calculated:** Reliable Model G5-56 Concealed Pendent  
**No. of sprinklers calculated:** 10  
**In-rack demand:** N/A - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 274.23 - GPM @ 48.8443 - Psi  
**Type of system:** Wet  
**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:** Sept. 2012  
**Location:** Unum Hyd. #6 Congress St. and Johnson Rd.  
**Source:** Hydrant Flow Data

**Name of contractor:** Dean and Allyn, Inc.  
**Address:** 116 Lewiston Rd / Your Street Address 2 / Gray, ME 04039  
**Phone number:** (207) 657-5646  
**Name of designer:** ZJG  
**Authority having jurisdiction:** State of Maine Fire Dept.  
**Notes: (Include peaking information or gridded systems here.)**


# Water Supply Curve C

Dean and Allyn, Inc.  
Unum

Page 2  
Date 11/20/17

City Water Supply:  
C1 - Static Pressure : 67  
C2 - Residual Pressure: 60  
C2 - Residual Flow : 1316

Demand:  
D1 - Elevation : 17.035  
D2 - System Flow : 174.23  
D2 - System Pressure : 48.844  
Hose ( Demand ) : 100  
D3 - System Demand : 274.23  
Safety Margin : 17.771



# Fittings Used Summary

Dean and Allyn, Inc.  
Unum

Page 3  
Date 11/20/17

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
A	Alarm Rel E1 & E3							7.7	21.5		17		27	29								
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Y	Mechanical Tee	2	4	5	6	8	10.5	12.5	15.5	0	22	0	0	0	0	0	0	0	0	0	0	

## Unit Summary

Diameter Units                      Inches  
 Length Units                        Feet  
 Flow Units                            US Gallons per Minute  
 Pressure Units                       Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Dean and Allyn, Inc.  
Unum

Page 4  
Date 11/20/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	39.333	5.6	9.02	na	16.82	0.1	144	7.0
2	39.708		11.13	na				
3	40.042		11.27	na				
5	39.333	5.6	8.08	na	15.92	0.1	49	7.0
6	39.708		9.96	na				
7	39.333	5.6	9.11	na	16.91	0.1	89	7.0
8	40.042		10.33	na				
4	40.042		11.77	na				
9	40.042		12.07	na				
10	39.333	5.6	9.75	na	17.48	0.1	118	7.0
11	39.708		12.02	na				
12	39.333	5.6	10.4	na	18.06	0.1	85	7.0
13	40.042		12.68	na				
14	40.042		14.7	na				
16	39.333	5.6	9.88	na	17.6	0.1	176	7.0
17	39.708		11.56	na				
19	39.333	5.6	7.87	na	15.71	0.1	120	7.0
20	39.708		9.7	na				
21	39.333	5.6	9.31	na	17.08	0.1	168	7.0
22	40.042		10.56	na				
18	40.042		11.97	na				
23	40.042		12.29	na				
24	39.333	5.6	12.3	na	19.64	0.1	170	7.0
25	39.708		14.4	na				
26	40.042		14.93	na				
28	39.333	5.6	11.52	na	19.01	0.1	176	7.0
29	40.042		13.7	na				
30	40.042		15.7	na				
15	40.042		14.94	na				
27	40.042		15.24	na				
31	40.042		16.18	na				
32	40.042		19.51	na				
33	40.042		24.89	na				
34	40.042		26.95	na				
35	40.042		27.24	na				
36	13.25		40.71	na				
37	13.25		40.98	na				
38	13.25		41.36	na				
39	13.25		41.64	na				
40	13.25		42.0	na				
41	12.792		42.29	na				
42	12.792		42.33	na				
43	12.792		42.4	na				
TR	3.208		46.61	na				
BR	3.208		46.98	na				
MAN	-6.0		51.28	na				
UG	-6.0		51.31	na				
UG1	-6.0		51.32	na				
UG2	-6.0		51.36	na				
UG3	14.0		42.73	na				
TEST	0.0		48.84	na	100.0			

The maximum velocity is 13.2 and it occurs in the pipe between nodes 13 and 14

# Final Calculations - Hazen-Williams - 2007

Dean and Allyn, Inc.  
Unum

Page 5  
Date 11/20/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	16.82	1.049		0.0	24.000	9.024				
to		120.0		0.0	0.0	-0.162			K Factor = 5.60	
2	16.82	0.0945		0.0	24.000	2.268			Vel = 6.24	
2	0.0	1.049	E	2.0	1.000	11.130				
to		120.0		0.0	2.000	-0.145				
3	16.82	0.0947		0.0	3.000	0.284			Vel = 6.24	
3	0.0	1.049	T	5.0	0.333	11.269				
to		120.0		0.0	5.000	0.0				
4	16.82	0.0943		0.0	5.333	0.503			Vel = 6.24	
	0.0									
	16.82					11.772			K Factor = 4.90	
5	15.92	1.049		0.0	24.000	8.080			K Factor = 5.60	
to		120.0		0.0	0.0	-0.162				
6	15.92	0.0853		0.0	24.000	2.047			Vel = 5.91	
6	0.0	1.049	T	5.0	1.000	9.965				
to		120.0		0.0	5.000	-0.145				
8	15.92	0.0853		0.0	6.000	0.512			Vel = 5.91	
	0.0									
	15.92					10.332			K Factor = 4.95	
7	16.91	1.049		0.0	16.000	9.114			K Factor = 5.60	
to		120.0		0.0	0.0	-0.307				
8	16.91	0.0953		0.0	16.000	1.525			Vel = 6.28	
8	15.91	1.049	T	5.0	0.333	10.332				
to		120.0		0.0	5.000	0.0				
9	32.82	0.3255		0.0	5.333	1.736			Vel = 12.18	
	0.0									
	32.82					12.068			K Factor = 9.45	
4	16.82	1.38		0.0	11.875	11.772				
to		120.0		0.0	0.0	0.0				
9	16.82	0.0249		0.0	11.875	0.296			Vel = 3.61	
9	32.83	1.38	T	6.0	9.583	12.068				
to		120.0		0.0	6.000	0.0				
15	49.65	0.1840		0.0	15.583	2.867			Vel = 10.65	
	0.0									
	49.65					14.935			K Factor = 12.85	
10	17.48	1.049		0.0	24.000	9.745			K Factor = 5.60	
to		120.0		0.0	0.0	-0.162				
11	17.48	0.1015		0.0	24.000	2.435			Vel = 6.49	
11	0.0	1.049	T	5.0	3.000	12.018				
to		120.0		0.0	5.000	-0.145				
13	17.48	0.1014		0.0	8.000	0.811			Vel = 6.49	
	0.0									
	17.48					12.684			K Factor = 4.91	
12	18.06	1.049		0.0	24.000	10.405			K Factor = 5.60	
to		120.0		0.0	0.0	-0.307				
13	18.06	0.1078		0.0	24.000	2.586			Vel = 6.70	
13	17.49	1.049	T	5.0	0.333	12.684				
to		120.0		0.0	5.000	0.0				
14	35.55	0.3771		0.0	5.333	2.011			Vel = 13.20	

# Final Calculations - Hazen-Williams

Dean and Allyn, Inc.  
Unum

Page 6  
Date 11/20/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
14 to 15	0.0 35.55	1.38 120.0 0.0993		0.0 0.0 0.0	2.417 0.0 2.417	14.695 0.0 0.240			Vel = 7.63	
	0.0 35.55					14.935			K Factor = 9.20	
16 to 17	17.60 17.6	1.049 120.0 0.1027	E	2.0 0.0 0.0	16.000 2.000 18.000	9.878 -0.162 1.848			K Factor = 5.60 Vel = 6.53	
17 to 18	0.0 17.6	1.049 120.0 0.1028	T	5.0 0.0 0.0	0.333 5.000 5.333	11.564 -0.145 0.548			Vel = 6.53	
	0.0 17.60					11.967			K Factor = 5.09	
19 to 20	15.71 15.71	1.049 120.0 0.0832		0.0 0.0 0.0	24.000 0.0 24.000	7.867 -0.162 1.997			K Factor = 5.60 Vel = 5.83	
20 to 22	0.0 15.71	1.049 120.0 0.0832	T	5.0 0.0 0.0	7.000 5.000 12.000	9.702 -0.145 0.999			Vel = 5.83	
	0.0 15.71					10.556			K Factor = 4.84	
21 to 22	17.08 17.08	1.049 120.0 0.0972		0.0 0.0 0.0	16.000 0.0 16.000	9.307 -0.307 1.556			K Factor = 5.60 Vel = 6.34	
22 to 23	15.71 32.79	1.049 120.0 0.3248	T	5.0 0.0 0.0	0.333 5.000 5.333	10.556 0.0 1.732			Vel = 12.17	
	0.0 32.79					12.288			K Factor = 9.35	
18 to 23	17.60 17.6	1.38 120.0 0.0270		0.0 0.0 0.0	11.875 0.0 11.875	11.967 0.0 0.321			Vel = 3.78	
23 to 27	32.79 50.39	1.38 120.0 0.1892	T	6.0 0.0 0.0	9.583 6.000 15.583	12.288 0.0 2.948			Vel = 10.81	
	0.0 50.39					15.236			K Factor = 12.91	
24 to 25	19.64 19.64	1.049 120.0 0.1258	E	2.0 0.0 0.0	16.000 2.000 18.000	12.302 -0.162 2.265			K Factor = 5.60 Vel = 7.29	
25 to 26	0.0 19.64	1.049 120.0 0.1260	T	5.0 0.0 0.0	0.333 5.000 5.333	14.405 -0.145 0.672			Vel = 7.29	
26 to 27	0.0 19.64	1.049 120.0 0.1258		0.0 0.0 0.0	2.417 0.0 2.417	14.932 0.0 0.304			Vel = 7.29	
	0.0									

# Final Calculations - Hazen-Williams

Dean and Allyn, Inc.  
Unum

Page 7  
Date 11/20/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	19.64					15.236			K Factor = 5.03	
28 to 29	19.00 19.0	1.049 120.0 0.1184	T	5.0 0.0	16.000 5.000	11.518 -0.307			K Factor = 5.60	
29 to 30	0.0 19.0	1.049 120.0 0.1184	T	5.0 0.0	11.875 5.000	13.697 0.0			Vel = 7.05	
30 to 31	0.0 19.0	1.38 120.0 0.0311	T	6.0 0.0	9.583 6.000	15.695 0.0			Vel = 7.05	
	0.0 19.00					16.180			K Factor = 4.72	
15 to 27	85.19 85.19	2.635 120.0 0.0214		0.0 0.0	14.042 0.0	14.935 0.0			Vel = 5.01	
27 to 31	70.03 155.22	2.635 120.0 0.0649		0.0 0.0	14.542 0.0	15.236 0.0			Vel = 9.13	
31 to 32	19.01 174.23	2.635 120.0 0.0805	T E	16.474 8.237	16.625 24.711	16.180 0.0			Vel = 10.25	
32 to 33	0.0 174.23	2.635 120.0 0.0804	T	16.474 0.0	50.417 16.474	19.506 0.0			Vel = 10.25	
33 to 34	0.0 174.23	4.26 120.0 0.0078	T 10E	26.334 131.671	108.458 158.005	24.887 0.0			Vel = 3.92	
34 to 35	0.0 174.23	4.26 120.0 0.0077	E	13.167 0.0	23.167 13.167	26.954 0.0			Vel = 3.92	
35 to 36	0.0 174.23	4.26 120.0 0.0078	Y 5T G E	28.968 131.671 2.633 13.167	64.708 176.439 241.147	27.235 11.604 1.870			Vel = 3.92	
36 to 37	0.0 174.23	5.295 120.0 0.0027	E T	15.158 31.579	53.583 46.737	40.709 0.0			Vel = 2.54	
37 to 38	0.0 174.23	5.295 120.0 0.0027	E	15.158 0.0	128.583 15.158	40.978 0.0			Vel = 2.54	
38 to 39	0.0 174.23	5.295 120.0 0.0027	E	15.158 0.0	86.708 15.158	41.365 0.0			Vel = 2.54	
39 to 40	0.0 174.23	5.295 120.0 0.0027	E	15.158 0.0	117.625 15.158	41.639 0.0			Vel = 2.54	
40 to 41	0.0 174.23	5.295 120.0 0.0027	E	15.158 0.0	19.250 15.158	41.996 0.198			Vel = 2.54	



# Final Calculations - Hazen-Williams

Dean and Allyn, Inc.  
Unum

Page 8  
Date 11/20/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
41	0.0	5.295	E	15.158	0.542	42.286				
to		120.0		0.0	15.158	0.0				
42	174.23	0.0027		0.0	15.700	0.043		Vel =	2.54	
42	0.0	5.295	E	15.158	10.208	42.329				
to		120.0		0.0	15.158	0.0				
43	174.23	0.0027		0.0	25.366	0.068		Vel =	2.54	
43	0.0	5.295	E	15.158	9.667	42.397				
to		120.0		0.0	15.158	4.151				
TR	174.23	0.0027		0.0	24.825	0.066		Vel =	2.54	
TR	0.0	4.26	G	2.633	9.583	46.614				
to		120.0	A	22.384	38.184	0.0				
BR	174.23	0.0078	E	13.167	47.767	0.371		Vel =	3.92	
BR	0.0	4.26	T	26.334	8.021	46.985				
to		120.0	Eq	5.267	31.601	3.988				
MAN	174.23	0.0077		0.0	39.622	0.307		Vel =	3.92	
MAN	0.0	6.16	E	20.084	9.208	51.280				
to		140.0		0.0	20.084	0.0				
UG	174.23	0.0010		0.0	29.292	0.028		Vel =	1.88	
UG	0.0	6.16	F	10.042	7.000	51.308				
to		140.0		0.0	10.042	0.0				
UG1	174.23	0.0010		0.0	17.042	0.017		Vel =	1.88	
UG1	0.0	6.16	E	20.084	14.458	51.325				
to		140.0		0.0	20.084	0.0				
UG2	174.23	0.0010		0.0	34.542	0.033		Vel =	1.88	
UG2	0.0	8.27	F	14.234	136.292	51.358				
to		140.0		0.0	14.234	-8.662				
UG3	174.23	0.0002		0.0	150.526	0.035		Vel =	1.04	
UG3	0.0	8.27	T	55.354	161.542	42.731				
to		140.0		0.0	55.354	6.063				
TEST	174.23	0.0002		0.0	216.896	0.050		Vel =	1.04	
	100.00							Qa =	100.00	
	274.23					48.844		K Factor =	39.24	