

SECTION 15940 - SEQUENCE OF OPERATIONS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes control sequences for HVAC systems, subsystems, and equipment.
- B. Related Sections include the following: Division 15 Section "HVAC Instrumentation and Controls" for control equipment and devices and submittal requirements.

1.3 VENTILATION SEQUENCES

- A. Kitchen Ventilation
 - 1. Exhaust and supply fans operate from a single switch by manufacturer supplied controls.
 - 2. Motorized fire damper controlled by the exhaust fan. When fan is energized the motorized fire damper opens 100% and when the fan is de-energized the motorized fire damper closes 100%.
 - 3. Motorized damper controlled by the supply fan. When fan is energized the motorized damper opens 100% and when the fan is de-energized the motorized damper closes 100%.

PART 2 - PRODUCTS (Not Applicable)

PART 3 - EXECUTION (Not Applicable)

END OF SECTION 15940

SEQUENCE OF OPERATIONS