Report of Field Density

ASTM D6938

Project: **PORTLAND ME - 1945 CONGRESS STREET - CONSTRUCTION MATERIALS TESTING SERVICES**

Project Number: **16-1446**

Client: **NORTHLAND ENTERPRISES LLC**

Field Density Test Results

Test #	Test Date	Tech	Test Location	Elev Feet	Test Depth	Lab ID	Dry Density	Moisture Content Percent	Compaction Percent	Required Compaction
1	6/7/2017	CLC	INTERIOR BETWEEN C & D-LINE OFF 1-LINE	2' BTW	12	22471G	118.1	6.5	99.2	95
2	6/7/2017	CLC	INTERIOR OFF A-LINE ON 6-LINE	2' BTW	12	22471G	113.4	6.8	95.3	95
3	6/7/2017	CLC	INTERIOR BETWEEN A & B-LINE OFF 9-LINE	4' BTW	8	22471G	113.1	6.5	95.0	95

Laboratory Compaction Test Reference

Lab ID	Date Received	Material Source	Material Type	Method	Max Dry Density	Optimum Moisture Content (%)	Comments
22471G	6/8/2017	SPTS	Common Borrow	ASTM D-1557 Modified A	119.0	11.7	

Elevation Notes:

BTW= BELOW TOP OF WALL

Comments:

Reviewed By