1 | ELECTRICAL LIFE SAFETY PLAN
1/8" = 1'-0"

FACP FIRE ALARM CONTROL PANEL

ANN FIRE ALARM ANNUNCIATOR PANEL

30 MH V FIRE ALARM AUDIO/VISUAL, MOUNT 6'-8"AFF, NUMBER DENOTES CANDELA RATING. "MH" DENOTES MINIHORN, "V" DENOTED VOICE EVACUATION. NO DESIGNATION EQUALS 15cd

F FIRE ALARM PULL STATION, MOUNT 48"AFF

15 CL SM FIRE ALARM VISUAL STROBE ONLY, FLUSH MOUNT 6'-8" AFF, NUMBER DENOTES CANDELA RATINGS. "CL" DENOTES CEILING MOUNTED

SCO SYSTEM CONNECTED SMOKE / CARBON MONOXIDE DETECTOR, PHOTOELECTRIC TYPE

135° HD SYSTEM CONNECTED FIXED TEMPERATURE HEAT DETECTOR

SD SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED.

ER SD SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED. "ER" DENOTES ELEV RECALL

SB SD SYSTEM CONNECTED SMOKE DETECTOR, PHOTOELECTRIC TYPE, WITH SOUNDER BASE

CO CARBON MONOXIDE DETECTOR

SD DUCT SMOKE DETECTOR & TEST STATION

FD/SD FIRE/SMOKE DAMPER, SUPPLIED AND INSTALLED BY MECHANICAL CONTRACTOR. ELECTRICAL CONTRACTOR TO PROVIDE ALL WIRING CONNECTIONS AND FIRE ALARM DUCT SMOKE DETECTORS, ADDRESSABLE MODULES AND PROGRAMMING.

K KNOX BOX

SPRINKLER SYSTEM FLOW SWITCH
SPRINKLER SYSTEM TAMPER SWITCH
} SUPPLIED BY SPRINKLER CONTRACTOR WIRED BY EC, VERIFY LOCATIONS WITH SPRINKLER CONTRACTOR.

SELF CONTAINED EMERGENCY LIGHT W/2 HEADS DUAL-LITE (LED) MODEL LZ65I-03L, 65 WATTS FOR 90 MINUTES, COLOR BY ARCHITECT

UNIVERSAL MOUNTED, DOUBLE FACED EXIT LIGHT PROVIDE DIRECTIONAL ARROWS AS INDICATED ON PLAN

UNIVERSAL MOUNTED, SINGLE FACED EXIT LIGHT PROVIDE DIRECTIONAL ARROWS AS INDICATED ON PLAN

2 | ELECTRICAL SYMBOLS
NOT TO SCALE

STATE OF MAINE
STEVEN J. MONASON
#8468
LICENSED
PROFESSIONAL ENGINEER
Date: 05/02/17

Reviewed for Code Compliance
Inspections Division
Portland, Maine

Prepared For:

Consultant:
BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 ARCHETYPE@ARCHETYPEPA.COM

Project:
Elks Lodge
Portland, Maine

Revisions:

Scale: 1/8" = 1'-0"

Date: 04/12/2017

ELECTRICAL LIFE SAFETY

ELS-1