
LEGEND

S	SINGLE POLE SWITCH - MOUNTED 48" AFF TO TOP
$S_{\scriptscriptstyle 3}$	THREE WAY SWITCH - MOUNTED 48" AFF TO TOP
$S_{\scriptscriptstyle{4}}$	FOUR WAY SWITCH - MOUNTED 48" TO TOP
S_{\scriptscriptstyleM}	MOTION SENSING SWITCH - MOUNTED 48" TO TOP
\Diamond	SPECIALTY OUTLET 30A AND UP - DEPENDANT ON EQUIPMENT - SEE PANEL SCHEDULE
Ш	GFI RECEPTACLE - MOUNTED 18" AFF TO CENTER UNLESS NOTED OTHERWISE
Ф	DUPLEX OUTLET - MOUNTED 18" AFF TO CENTER UNLESS NOTED OTHERWISE
	DOUBLE DUPLEX OUTLET -MOUNTED 18" AFF TO CENTER UNLESS NOTED OTHERWISE
J	JUNTION BOX - SIZED AS REQUIRED
	DISCONNECT SWITCH - FUSED AS REQUIRED (DIAGONAL LINE INDICATES FUSED)
\otimes	EXIT LIGHT W/ LED LAMPS
	EMERGENCY LIGHT BATTERY UNIT
T	DATA OUTLET LOCATION (SINGLE CABLE)
lacktriangle	DATA OUTLET LOCATION (TWO CABLES)
	FLOOR BOX POWER
<u></u>	CEILING MOTION SENSOR
R	RELAY
GFI	GROUND FAULT INTERRUPTER W/ SURGE SUPPRESSION
EWC	ELECTRIC WATER COOLER
EF	EXHAUST FAN
WP	WEATHERPROOF
TV	TV/COAX/RG6 DROP
FBO	FURNISHED BY OTHERS
С	COUNTER HEIGHT (SEE MILLWORK DRAWINGS)
Н	HOSPITAL GRADE DEVICE W/ RED FACEPLATE
IG	ISOLATED GROUND DEVICE
FB	FLOOR BOX
DTT	DRY TYPE TRANSFORMER
	FIRE ALARM SYSTEM
F	MANUAL PULL STATION - MOUNTED 48" AFF TO CENTER
F	HORN STROBE UNIT - MOUNT 80" AFF TO CENTER - EXCEPTION NO CLOSER THAN 6' TO CEILING
$\stackrel{3}{ riangle}$	VISUAL STROBE ONLY UNIT - MOUNT 80" AFF TO CENTER
S	SMOKE DETECTOR
Sco	SMOKE/CO COMBINATION DETECTOR
\bigcirc	HEAT DETECTOR
T	SPRINKLER TAMPER SWITCH
FL	SPRINKLER WATERFLOW SWITCH
ANN	FIRE ALARM ANNUNCIATOR

FIRE ALARM CONTROL PANEL



B·H·Milliken ELECTRICAL CONTRACTORS

235 PRESUMPSCOT STREET PORTLAND, MAINE 04103 207.879.1877

MEDICAL OFFICES
DR. BEDECS
1945 CONGRESS STREET
PORTLAND, MAINE

TITLE:

LEGEND

SCALE: NTS

DATE: 4/5/17

SHEET:

E-000