Inspections Division
Date: 11/20/17

HVAC SERVICES, INC.

• ventilation • air conditioning • programmable thermostats • energy management • maintenance contracts • solar • computer rooms • geothermal • 24 hour service • air quality • heating - heat pumps • ventilation • air conditioning

Single Wall Round

Construction Standards for Single Wall Round Spiral Pipe and Fittings

Galvanized Steel (ASTM A 527)

Plus 2" w.g.

Max. Dia	Pipe Ga.	Fitting Ga.
3" - 6"	28	26
7" - 8"	28	26
9" - 10"	28	26
11" - 12"	28	26
13" - 14"	28	26
15" - 16"	28	26
17" - 18"	28	26
19" - 26"	28	24
27" - 30"	28	24

Contact factory for construction standards for other pressure classes.

73 BRADLEY DRIVE • WESTBROOK, ME 04092
(207) 854-4822 (HVAC) • Fax: (207) 854-0775

• energy management • maintenance contracts • solar • computer rooms • geothermal • 24 hour service • air quality • heating - heat pumps • ventilation • air conditioning • programmable thermostats • energy management • maintenance contracts • solar • computer rooms • geothermal • 24 hour service • air quality • heating - heat pumps • ventilation • air conditioning