



**... Fire Protection by Computer Design**

HIGH TECH FIRE PROTECTION  
84 HACKETT MILLS ROAD  
P.O. BOX 156  
POLAND, ME 04274  
207-998-2551

Job Name : Clark Insurance conditioned attic #2  
Drawing : FP-01  
Location : 1945 Congress Street  
Remote Area : #2  
Contract :  
Data File : Wet Attic.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**Project name:** Clark Insurance conditioned attic  
**Location:** 1945 Congress Street  
**Drawing no:** FP-01  
**Date:** 8/18/17

**Design**

**Remote area number:** #2  
**Remote area location:** Conditioned attic space  
**Occupancy classification:** Light Hazard  
**Density:** .1 - Gpm/SqFt  
**Area of application:** 5-head spec - SqFt  
**Coverage per sprinkler:** 240 - SqFt  
**Type of sprinklers calculated:** back to back attic heads  
**No. of sprinklers calculated:** 5  
**In-rack demand:** n/a - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 223 - GPM @ 61 - Psi  
**Type of system:** Wet System  
**Volume of dry or preaction system:** n/a - Gal

**Water supply information**

**Date:** 8-11-17  
**Location:** Corner of Congress St and International Parkway  
**Source:** Portland Water District

**Name of contractor:** HIGH TECH FIRE PROTECTION  
**Address:** 84 HACKETT MILLS ROAD / P.O. BOX 156 / POLAND, ME 04274  
**Phone number:** 207-998-2551  
**Name of designer:** Ed Poulin  
**Authority having jurisdiction:** State of Maine / City of Portland  
**Notes: (Include peaking information or gridded systems here.)**


# Water Supply Curve (C)

HIGH TECH FIRE PROTECTION  
Clark Insurance conditioned attic #2

Page 2  
Date 8/18/17

City Water Supply:  
C1 - Static Pressure : 85  
C2 - Residual Pressure: 80  
C2 - Residual Flow : 1378

Demand:  
D1 - Elevation : 9.528  
D2 - System Flow : 122.8  
D2 - System Pressure : 60.715  
Hose ( Demand ) : 100  
D3 - System Demand : 222.8  
Safety Margin : 24.114



# Fittings Used Summary

HIGH TECH FIRE PROTECTION  
Clark Insurance conditioned attic #2

Page 3  
Date 8/18/17

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
Length Units                       Feet  
Flow Units                         US Gallons per Minute  
Pressure Units                   Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION  
Clark Insurance conditioned attic #2

Page 4  
Date 8/18/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	8	10.3	na	25.67	0.1	256	10.3
200	35.0	5.6	18.4	na	24.02	0.1	240	18.4
201	35.0	5.6	18.5	na	24.08	0.1	240	18.4
202	35.0	5.6	18.85	na	24.31	0.1	240	18.4
203	35.0	5.6	19.6	na	24.79	0.1	240	18.4
204	35.0	5.6	20.89	na	25.59	0.1	240	18.4
205	35.0		27.57	na				
206	25.0		39.36	na				
207	25.0		40.1	na				
208	15.0		45.06	na				
209	15.0		46.74	na				
210	10.0		49.36	na				
AI	10.0		50.58	na				
TOR	10.0		52.25	na				
FLW	5.0		57.63	na				
BOR	0.0		66.07	na				
H1	0.0		66.2	na				
H2	0.0		66.22	na				
H3	0.0		66.23	na	100.0			
TEST	13.0		60.71	na				

The maximum velocity is 17.73 and it occurs in the pipe between nodes 204 and 205

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
Clark Insurance conditioned attic #2

Page 5  
Date 8/18/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	25.67	1.049 120.0 0.2065	1T	5.0 0.0 0.0	1.000 5.000 6.000	10.300 -0.433 1.239			K Factor = 8.00	
	0.0 25.67						11.106		K Factor = 7.70	
200 to 201	24.02	1.682 120.0 0.0183		0.0 0.0 0.0	5.300 0.0 5.300	18.400 0.0 0.097			K Factor = 5.60	
	24.02								Vel = 3.47	
201 to 202	24.09	1.682 120.0 0.0662		0.0 0.0 0.0	5.300 0.0 5.300	18.497 0.0 0.351			K Factor = 5.60	
	48.11								Vel = 6.95	
202 to 203	24.31	1.682 120.0 0.1411		0.0 0.0 0.0	5.300 0.0 5.300	18.848 0.0 0.748			K Factor = 5.60	
	72.42								Vel = 10.46	
203 to 204	24.79	1.682 120.0 0.2432		0.0 0.0 0.0	5.300 0.0 5.300	19.596 0.0 1.289			K Factor = 5.60	
	97.21								Vel = 14.04	
204 to 205	25.59	1.682 120.0 0.3749	1V	4.331 0.0 0.0	13.500 4.331 17.831	20.885 0.0 6.685			K Factor = 5.60	
	122.8								Vel = 17.73	
205 to 206	0.0	1.682 120.0 0.3749	1X	9.9 0.0 0.0	10.000 9.900 19.900	27.570 4.331 7.460				
	122.8								Vel = 17.73	
206 to 207	0.0	2.635 120.0 0.0421	1V	5.903 0.0 0.0	11.600 5.903 17.503	39.361 0.0 0.737				
	122.8								Vel = 7.22	
207 to 208	0.0	2.635 120.0 0.0421	1V	5.903 0.0 0.0	9.000 5.903 14.903	40.098 4.331 0.628				
	122.8								Vel = 7.22	
208 to 209	0.0	2.635 120.0 0.0421	1V	5.903 0.0 0.0	34.000 5.903 39.903	45.057 0.0 1.681				
	122.8								Vel = 7.22	
209 to 210	0.0	2.635 120.0 0.0420	1V	5.903 0.0 0.0	5.000 5.903 10.903	46.738 2.166 0.458				
	122.8								Vel = 7.22	
210 to AI	0.0	2.635 120.0 0.0421	1X	14.827 0.0 0.0	14.000 14.827 28.827	49.362 0.0 1.215				
	122.8								Vel = 7.22	
	0.0 122.80						50.577		K Factor = 17.27	
AI to TOR	122.80	2.635 120.0 0.0421	2V	11.807 0.0 0.0	28.000 11.807 39.807	50.577 0.0 1.676				
	122.8								Vel = 7.22	
TOR to FLW	0.0	2.635 120.0 0.0420	1Fsp	0.0 0.0 0.0	5.000 0.0 5.000	52.253 5.166 0.210			* Fixed loss = 3	
	122.8								Vel = 7.22	
FLW to BOR	0.0	2.635 120.0 0.0430	1Zia	0.0 0.0 0.0	1.000 0.0 1.000	57.629 8.394 0.043			* Fixed loss = 6.229	
	122.8								Vel = 7.22	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
Clark Insurance conditioned attic #2

Page 6  
Date 8/18/17

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BOR	0.0	6.16	1F	10.042	250.000	66.066			
to		140.0	1G	4.304	14.346	0.0			
H1	122.8	0.0005		0.0	264.346	0.133	Vel =	1.32	
H1	0.0	8.27	1T	55.354	140.000	66.199			
to		140.0	1G	6.326	61.680	0.0			
H2	122.8	0.0001		0.0	201.680	0.025	Vel =	0.73	
H2	0.0	12.34	1T	93.767	95.000	66.224			
to		140.0		0.0	93.767	0.0			
H3	122.8	0.0		0.0	188.767	0.003	Vel =	0.33	
H3	100.00	6.16	1G	4.304	10.000	66.227	Qa =	100	
to		140.0	1E	20.084	67.425	-5.630			
TEST	222.8	0.0015	1T	43.037	77.425	0.118	Vel =	2.40	
	0.0								
	222.80					60.715	K Factor =	28.59	